



# Certificate of Compliance

**Certificate:** 1665655

**Master Contract:** 240515

**Project:** 70176532

**Date Issued:** 2018-06-07

**Issued to:** Telemecanique/Schneider Electric Industries SAS  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
FRANCE

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Khalil Ouldchama*  
Khalil Ouldchama

## **PRODUCTS**

CLASS - C321103 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Auxiliary Devices

Inductive proximity switches, Cat. No. XS1 or XS2, followed by 06, 08, 12, 18 or 30, followed by A or B, followed by L, F or H, followed by P or N, followed by A or B, followed by L with a one or two digit number, M8 or M12, may be followed by one, two or three alpha or alpha-numeric suffix.

Ratings: 12 - 24 Vdc, 100 mA max (output), for XS1 or XS2 followed by 06 or 08; 12 - 24 Vdc, 200 mA max (output) for XS1 or XS2 followed by 12, 18 or 30. Enclosure Type 1, 4X indoor use, 12 or 13, for XS1... or XS2... followed by A; Type 1, 4X, 12 or 13 for XS1... or XS2... followed by B.

## **APPLICABLE REQUIREMENTS**

CSA-C22.2 No.14-13 - Industrial Control Equipment  
CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures