



# Certificate of Compliance

**Certificate:** 2565371

**Master Contract:** 240515

**Project:** 2565371

**Date Issued:** October 12, 2012

**Issued to:** Telemecanique/Schneider Electric

**Industries SAS**  
**Zone Industrielle No. 3**  
**L'Isle d'Espagnac, 16340**  
**France**  
**Attention: Mr. Christophe Delaitre**

*The products listed below are eligible to bear the CSA Mark shown*



*J.-C. Chow*

**Issued by:** J.-C. Chow

## **PRODUCTS**

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Limit switches, Cat. No. XCKVR, followed by two-digit number followed by D or SR followed by 1 or 2 followed by a H29 or H7; rating codes A300, Q300; special purpose enclosure Type 4X Indoor use or 12K.

### Notes:

1. The limit switches without NPT conduit entry may be marked with special purpose enclosure rating when provided with instructions in package indicating the kit of NPT-Metric adaptors necessary to maintain the effectiveness of the special purpose rating and the NPT conduit entry.
2. These limit switches are certified as end-of-line auxiliary devices, where only one conduit is to be connected to the enclosure.

## **APPLICABLE REQUIREMENTS**

CSA-C22.2 No. 14-10 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures