



Certificate of Compliance

Certificate: 2711121

Master Contract: 240515

Project: 2711121

Date Issued: March 26, 2014

Issued to: Telemecanique/Schneider Electric

Industries SAS
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France
Attention: Mr. Christophe Delaître

The products listed below are eligible to bear the CSA Mark shown



J.-C. Chow

Issued by: J.-C. Chow

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Trip-wire-operated emergency-stop switches, Model XY2CJ, contact-rating: A300 and Q300, for two-contacts (1NC+1NO, or 2NC) model; B300 and R300, for three-contacts (2NC+1NO, or 1NC+2NO) model; enclosure Type 4 or 12.

Note: Enclosure Type 4 or 12 only when provided with 1/2-inch NPT threaded entries, or with metric-NPT adaptors for trade size conduits.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-13 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures