



CSA INTERNATIONAL

# Certificate of Compliance

## USINE

Certificate Number: LR 44087-149

Revision: LR 44087-149

Date Issued: August 19, 1999

Issued to: **TELEMECANIQUE/SCHNEIDER ELECTRIC S.A.**  
33 Bis Avenue du Maréchal Joffre  
B.P. 204  
F-92002 Nanterre Cedex  
France

*The products listed below are eligible to bear the CSA Mark shown*



Issued by: M. Legault, Eng.

Signature: \_\_\_\_\_

### PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Pressure operated switches, polymeric enclosure, Cat. No. XMP, rated 2 hp 120V, 3 hp 240V ac, 1 ph, 2 poles; 3 hp 120V, 5 hp 240V, 1 hp 600V ac, 3 ph and/or rated A600. Enclosure Type 1.

Pressure operated switches, polymeric enclosure, Cat. Nos. XMA and XMX, rated B300, Q300 pilot duty. Contacts of same polarity. Enclosure Type 12.

### Notes:

1. The type designation is completed with numbers and letters indicating operating pressure and mechanical details.
2. The switches without NPT conduit entries are accepted as "Special Component Devices" having a general purpose enclosure and are only for use where the acceptability of the combination is to be determined by the Canadian Standard Association.
3. The devices over 300V are certified as components for use in circuits where the short circuit capacity is limited by fuses having ratings not exceeding the ratings of the device.

### APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-95	-	Industrial Control Equipment
CAN/CSA-C22.2 No. 94-M91	-	Special Purpose Enclosures