



# Certificate of Compliance

**Certificate:** 2155978

**Master Contract:** 225619

**Project:** 2589421

**Date Issued:** December 21, 2012

**Issued to:** Telemecanique/Schneider Electric

Industries SAS.  
BP 660  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
France  
Attention: Mr. Jean-Pierre Laidet

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



J.-C. Chow

Issued by: J.-C. Chow

## **PRODUCTS**

**CLASS 3211 83** - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Auxiliary Devices-Certified to U.S. Standards

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Biometric switch, fingerprint reader, open type, Cat. No. XB5 S, followed by 1, 2, 3, 4 or 5, followed by B, followed by 2, followed by L with a number or followed by M12; rated 24 Vdc supply, 200 mA PNP-output, resistive, protected against overload and short-circuit; enclosure Type 12.

## **Notes:**

- 1) These open type devices are certified for use in other Certified equipment where the suitability of the combination is to be determined by CSA International.
- 2) Non-evaluated as a biometric operating device where its suitability within the en-use application shall require further evaluation should this feature be considered critical for safety.

## **APPLICABLE REQUIREMENTS**



**Certificate:** 2155978

**Master Contract:** 225619

**Project:** 2589421

**Date Issued:** December 21, 2012

---

CSA-C22.2 No. 14-10 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

ANSI/UL 508 (17th Edition) - Industrial Control Equipment

ANSI/UL 50E (1st Edition) - Enclosures for Electrical Equipment, Environmental Considerations.