



Certificate of Compliance

Certificate Number: LR 92886-50

Revision: LR 92886-88

Date Issued: December 8, 1998

Issued to: SQUARE D CO.
3700 - 6th St., S.W.
Cedar Rapids, IA 52404
USA
Attention: Mr. Jan Harper

The products listed below are eligible to bear the CSA Mark shown



Issued by: R. Tateishi, P. Eng.
Toronto, ON Canada

Signature: 

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, moulded case, Type QOU, Series 1, 1- and 2-pole common trip, 80-100A, 120/240V ac, 60V dc per pole; 3-pole common trip, 60-100A, 240V ac, 60V dc per pole; thermal-magnetic trip, uncompensated, calibrated to 40C (Option B) requirements.

APPLICABLE STANDARDS

CAN/CSA-C22.2 No. 5.1-M91 - Moulded Case Circuit Breakers