



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA202009

Certificate Holder: Schneider Electric Solar Inc
3700 Gilmore Way, Burnaby,
British Columbia V5G 4M1,
Canada

Regulatory Definition: Non-Prescribed
Product Description: Solar Charge Controller
Trade Name: Schneider Electric Solar Inc.
Model No.: Conext MPPT 60 150
Rating/Marking: MPP DC voltage range: 12-140Vdc
Input DC voltage range: 0-150Vdc
Input DC current: Max 60A
Output battery voltage: nom. 12, 24, 36, 48, 60Vdc
Output battery current: Max 60A

Standard: IEC 62109-1 Ed. 1.0
Conditions: Nil

Certification Mark: RCM and SAA202009

Date First Registered: 13 August 2020
Date of Expiry: 13 August 2025

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 13-08-20 202009/1