

Certificate No.: SGS/150299

CERTIFICATE OF SUITABILITY

This certificate is issued to confirm that **SGS Systems & Services Certification Pty Ltd** (Electrical Product Certification Services (EPCS) Australia) as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has certified the article described herein to comply with the minimum safety standards for which the Application has been made by :-

SCHNEIDER ELECTRIC (AUSTRALIA) PTY LTD
33-37 Port Wakefield Road
GEPPS CROSS SA 5094
AUSTRALIA

DESCRIPTION OF ELECTRICAL EQUIPMENT

Product: Solar Grid Inverter
(Grid Connected Inverter Energy System)

Trade Name / Manufacturer: Schneider Electric; Conext TL

Catalogue / Model No(s): PVSNVC15000; PVSNVC20000

Ratings: Input:- 200-1000 V d.c.; Max. 1000 V d.c.; (MPPT 350-800 V d.c.);
Class I; IP65;
PVSNVC15000: 2 x 23 A;
PVSNVC20000: 2 x 30 A

Output:- 230 V a.c. / 400 V a.c. (3N~); 50 Hz;
PVSNVC15000: Max. 24 A, 15 kVA;
PVSNVC20000: Max. 32 A, 20 kVA


Standard No.: AS/NZS 3100:2009 + A1
AS 4777.2:2005 and AS 4777.3:2005
IEC 62109-2:2011 with IEC 62109-1:2010

REQUIRED MARKING: SGS-150299-E

EXPIRY DATE: 27 May 2020

DATE OF CERTIFICATION: 28 May 2015

JAS-ANZ



www.jas-anz.org/register

For and On Behalf of
SGS Systems & Services Certification Pty Ltd

