



08/04/01/014464

D. Marc Capdevila Figueras, Inspector of ECA S.A.U., the Group Bureau Veritas, Organization of Inspection and Audit, certifies in reference to the UNE EN 9001-200.

CERTIFY:

That as requested by the company: "SCHNEIDER ELECTRIC INDUSTRIES S.A" DBA (doing business as) "HISPANO MECANO ELÉCTRICA, S.A.- HIMEL." and its representative Ms. Susanna Cabos, Person in charge of Quality and external certifications, we were proceeded in yours installation in C / Call, 64, CAPELLADES (Barcelona), to verify the business name changes for social name changes in the Bureau Veritas certificate with nº 08/04/1/014464 dated 9/12/2009.

The concepts test and the number certificate nº 08/04/1/014464 are:

Visits of Inspection, Testing, and Test Sets Envelopes Aimed at low-voltage switchgear, GAMA NSYCRN (Spacial CRN series), duly reviewed, signed and sealed, for models:

One door with and without suffix T

NSYCRN108300T, NSYCRN75200, NSYCRN55250T, NSYCRN252150

That, according to the above, and in given the results obtained, I consider that the wrappings for the GAMA NSYCRN (Spacial CRN series) low-pressure related devices COMPLY SATISFACTORILY with the requirements of the standard IEC 62208 and all other regulations that may arise, according to the following specifications of the standard:

SECTION OF THE STANDARD	TEST	RESULTS
9.3	Static loads	Admisible load plate: 250kg/m ² Admisible load door: 50 Kg/m ²
9.4	Lifting	Not applicable
9.5	Axial loads	Not applicable
9.6	IK Code	IK-10
9.7	IP Code	IP-66
9.8.1	Thermal stability	Not applicable
9.8.2	Heat resistance	Not applicable
9.8.3	Abnormal heat and fire	Not applicable
9.9	Dielectric strength	Not applicable
9.10	Continuity of the protective circuit	< 0.1 Ohms
9.11	Weather resistance	Compliant with the standard
9.12	Resistance to corrosion	External cycle
9.2	Marking	Compliant with the standard



Product changes, according to the relation:

HIMEL Product – Replaced Title	SCHNEIDER Product – New Title
CRN	NSYCRN (Spacial CRN series)
One door with and without suffix KT	One door with and without suffix T
108/300 KT	NSYCRN108300T
75/200	NSYCRN75200
55/250 KT	NSYCRN55250T
2520/150	NSYCRN252150

This certificate replaces the certificate of Bureau Veritas 11/B50/04/0066 number, dated 17/06/2004-08/07/2004.

In witness whereof, signed sealed and delivered in Barcelona, ninth of December 2009.

Inspector

M. Capdevila Figueras

