

Certificate of Compliance

Certificate Number 20100414 – E103582E
Report Reference E103582, 2000 May 11
Issue Date 2010 April 14

Page 1 of 1



Issued to: **SCHNEIDER ELECTRIC INDUSTRIES**

**C/CALL 64
08786 CAPELLADES, SPAIN**

*This is to certify that
representative samples of*

Industrial Control Panels

Model Descriptions: Industrial Control Equipment Enclosures, Spacial SM and SMX Series with references NSYSM and NSYSMX with or without Suffix T.

NSYSM single door are rated Type 1, 2, 3, 3R, 4, 5, 12, 12K and 13. NSYSMX single door are rated Type 1, 2, 3, 3R, 4, 4X, 5, 12, 12K and 13. NSYSM and NSYSMX double door are rated Type 1, 12, 12K and 13.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **The basic standards used to investigate products in this category are UL 508A, "Industrial Control Panels" and CAN/CSA-C22.2 No. 14, "Industrial Control Equipment."**

Additional Information: **See UL On-line Certification Directory at www.ul.com for additional information.**

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers; the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>