

FR_645933/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Busbar trunking system

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS 35, rue Joseph Monier

92500 RUEIL MALMAISON

France

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS

31 rue Pierre Mendes France, Eybens 38050 GRENOBLE Cedex 9

France

Name and address of the factory

SCHNEIDER ELECTRIC FRANCE

6 - 8 rue du Bailly - BP 97812

21078 DIJON Cedex France

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

25 A or 40 A

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Canalis KBA

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 645933 dated 22/04/2014. (new factory)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61439-1:2011(ed.2) IEC 61439-6:2012(ed.1)

As shown in the Test Report Ref. No. which forms part of this Certificate

122711-645930, 122711-645930/A1

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques 33, avenue du Général Leclerc – BP8 FR 92 266 Fontenay aux Roses Cedex www.lcie.fr LABORATOIRE DENTRAL DES INDUSTRIES EL CONTROL SA.S au capital de 13/145/94 € RCS Nantere 14/08/53/174
33 Avenue du béneral Lecterc
F - 92266 EU/TENAY AUX ROSES

Date: 24/07/2017

Signature: Jean-François BRUEL Certification Officer



FR_645933/A1

ANNEX

Main characteristics

Busbar trunking systems KBA

Straight length busbar trunking units with tap-off facilities, flexible busbar trunking units, busbar trunking feeder units, fixing devices.

The unit includes one ribbon cable comprising of two conductors (phase and neutral) or four conductors (three phases and one neutral) mounted in an enclosure acting as a protective earth.

Disconficatellation (indeed author)	la de en installation
Place of installation (indoor / outdoor)	Indoor installation
Service conditions (normal / special)	Normal
Mobility (stationary / movable)	Stationary assembly
IP Code	IP 55
IK Code	IK08
Mechanical loads (normal / heavy / special)	Normal
Resistance to fire and flame propagation	Resistance to flame propagation
Mounting attitude	All
Pollution degree	3
Rated operational voltage (Ue /1 ph system)	230 V~
Rated operational voltage (Ue /2/3 ph system)	400 V~
Rated insulation voltage (Ui / all systems)	690 V
Rated impulse voltage (Uimp) :all systems	4 kV
Rated current (In):	25 A or 40 A
Rated short-time withstand current (Icw)	0,44 kA (In=25A) or 0,94 kA (In=40A)
Rated peak withstand current (lpk)	4,4 kA (In=25A) or 9,6 kA (In=40A)
Rated frequency (f):	50/60 Hz
Resistance and reactance values (at a conductor temperature of 35 °C):	
R	8,30 mΩ/m (In=25A) ; 3,46 mΩ/m (In=40A)
Х	0,70 mΩ/m (In=25A) ; 0,19 mΩ/m (In=40A)
Rating factors:	
- k1 _35°C	1,0
- k1 _40°C	0,96
- k1 _45°C	0,93
- k1 _55°C	0,85
Mounting factors:	
- k1c vertical mounting	1



LCIE – Laboratoire Central des Industries Electriques 33, avenue du Général Leclerc – BP8 FR 92 266 Fontenay aux Roses Cedex www.lcie.fr



Date: 24/07/2017 Signature: Jean-François BRUEL
Certification Officer