

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Wireless energy sensor
Acti9 PowerTag

Name and address of the applicant

Schneider Electric SE
35, rue Joseph Monier
92500 RUEIL MALMAISON
- FRANCE

Name and address of the manufacturer

Schneider Electric SE
35, rue Joseph Monier
92500 RUEIL MALMAISON
- FRANCE

Name and address of the factory

Schneider Electric SE
Zone Industrielle des Agriers
16000 ANGOULEME
- FRANCE

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

A9MEM1520, A9MEM1521, A9MEM1522, A9MEM1561,
A9MEM1562, A9MEM1563, A9MEM1560 : 230V 50/60Hz 1VA
A9MEM1540 : 3x400V 50/60Hz 2VA
A9MEM1541, A9MEM1542, A9MEM1570, A9MEM1571,
A9MEM1572 : 3x230/400V 50/60Hz 2VA

Trademark (if any)

SCHNEIDER ELECTRIC

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

A9MEM1520, A9MEM1521, A9MEM1522, A9MEM1540,
A9MEM1541, A9MEM1542, A9MEM1560, A9MEM1561,
A9MEM1562, A9MEM1563, A9MEM1570, A9MEM1571,
A9MEM1572

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 690110/M1 dated 08/11/2017. Addition of product references

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010
IEC 61010-2-030:2010

As shown in the Test Report Ref. No. which forms part of this Certificate

151391-711471-B Version : 01
151391-711471-C Version : 01

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 20/02/2018

Signature: **Gilles LEMONNIER**
Certification Officer