



Certificate of Compliance

Certificate: 1160039 (LR 92886-37)

Master Contract: 153555

Project: 2516417

Date Issued: April 25, 2012

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Jan Harper

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, Types QO and QOB, thermal magnetic trip, uncompensated, one-and two-pole, 10-70A, 240V ac max, 48V dc max and three-pole, 10-60A, 240V ac max, 48V dc max.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 1160039

Master Contract: 153555

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2516417	April 25, 2012	Increase in the VH ratings from 30A to 70A for the 1-pole circuit breakers.
2502249	February 27, 2012	Revised construction of the QO(B), QO(B)-VH and QH(B), 3-pole, 15-30A, circuit breakers.
2423526	May 10, 2011	Revised construction of the QO(B), QO(B)-VH and QH(B), 3-pole, 15-30A and the QO(B), 3-pole, 35-60A circuit breakers.
2381494	January 11, 2011	Revised wire temperature rating on the #6 AWG conductors to 75C only.
2333628	August 12, 2010	Addition of an arc stack on the QO(B), 3-pole, 10A circuit breakers.
2212629	August 26, 2009	Revised construction of the QO(B)-H, 2-pole, 15-30A circuit breakers.
1978847	December 13, 2007	Addition of an alternate arc chute/plate on the 240V, 35-60A, 10kA, 2- and 3-pole breakers.
1818390	October 13, 2006	Revised toggle spring on the 60 and 70A, 1- and 2-pole circuit breakers.
1680965	June 6, 2005	Addition of alternate case materials.

History

- 1239070 Sept. 4, 2001 Revised pigtail/coil on 10-20A, 1-pole breakers rated 22kA and 65kA.
- 1160039 Jan. 22, 2001 Deletion of compensator (Rawstock Spec No. 48001-004-47) for 10A single-pole breakers.
- 90 Nov. 12, 1998 Alternate bimetal rawstock for the 70A breakers.
- 89 July 14, 1998 Addition of ring terminal connector on 60A breakers.
- 70 Jan. 27, 1997 Addition of ring terminal connectors on 10-50A breakers.
- 66 July 15, 1996 Report revision to clarify HIC ratings.
- 60 Jan. 17, 1996 Addition of an arc stack on the 15-30A, 3-pole, QH and -VH constructions.
- 51 May 5, 1995 Revised construction of the 3-pole 15-30A, QH construction.
- 37 Oct. 5, 1993 Original Certification.