



# Certificate of Compliance

**Certificate:** 1402579 (LR 29971-43)

**Master Contract:** 153555

**Project:** 70059715

**Date Issued:** 2016-02-10

**Issued to:** Schneider Electric USA, Inc.  
Square D  
3700 6th St SW  
Cedar Rapids, Iowa 52404  
USA  
**Attention:** Manuel Salinas

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Ronald Tateishi*  
Ronald Tateishi

## PRODUCTS

CLASS 1451 01 - GROUND FAULT DEVICES - Circuit Interrupters

“Quick-Gard” combined circuit breaker and ground fault interrupter, Class A, open type, Type QO-GFI and QOB-GFI, Series 2, single-pole, 15-30A, 120V ac.

### Notes:

1. These circuit breakers are Certified for use only in enclosures where the suitability has been determined by CSA Group.
2. These circuit breakers are suitable for use where the Canadian Electrical Code, Part I requires that a “Class A” interrupter be used.
3. These circuit breakers may be marked with high-current interrupting ratings in RMS symmetrical amperes, as follows:

<u>Breaker Cat No</u>	<u>Voltage</u>	<u>Interrupting Ratings</u>
QO-GFI or QOB-GFI	120	10,000
QO-VHGFI or QOB-VHGFI	120	22,000



**Certificate:** 1402579 (LR 29971-43)  
**Project:** 70059715

**Master Contract:** 153555  
**Date Issued:** 2016-02-10

---

**APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

CSA Standard C22.2 No. 144.1 - Ground-Fault Circuit-Interrupters



## *Supplement to Certificate of Compliance*

**Certificate:** 1402579 (LR 29971-43)

**Master Contract:** 153555

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70059715	2016-02-10	Evaluation to the requirements of CSA Certification Notice “Ground Fault Circuit Interrupters No. 9A”, Ref No: N15-061.”.
2436483	2011-09-13	Addition of a new RoHS compliant circuit board, new manufacturer of the microprocessor, new board layout and firmware revisions.
2009516	2008-02-19	Revised value of resistor R7 on module 48155-437-50.
1812097	2006-11-01	Compliance to CSA Standard 144.1-06.
1581813	2004-08-03	Addition of alternate module (Model 48155-437-50)
1522143	2004-03-29	Addition of arc stack to single-pole devices.
1507595	2003-12-23	Compliance to the requirements of T.I.L. D-27