



Certificate of Compliance

Certificate Number: LR 92886-21

Revision: LR 92886-91

Date Issued: November 3, 1998

Issued to: **SQUARE D COMPANY**
3700 - 6th St. S.W.
Cedar Rapids, IA 52406
USA
Attention: Mr. Jan Harper

*The products listed below are eligible to bear the CSA Mark shown,
with adjacent indicator NRTL/C.*



Issued by: R. Tateishi, P. Eng.
Toronto, ON Canada

Signature: _____

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type
CLASS 1432 81 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, moulded case types, remote controlled, Cat Nos QO-PL and QOB-PL; 1-pole, 15-30A, 120/240V ac; 2-pole (common trip), 15-60A, 120/240V ac; 3-pole (common trip), 15-30A, 240V ac.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.	5.1-M91	-	Moulded Case Circuit Breakers
UL Std No.	489	-	Moulded-Case Circuit Breakers and Circuit Breaker Enclosures

The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.