



# Certificate of Compliance

**Certificate:** 1171581 (LR 80849)

**Master Contract:** 179014

**Project:** 2610687

**Date Issued:** April 4, 2013

**Issued to:** Schneider Electric Industries S A S

**Power Business Unit / FLV  
Electropole/EYBENS  
31 rue Pierre Mendes France  
Grenoble Cedex, 38050  
France  
Attention: Christophe Chabert**

*The products listed below are eligible to bear the CSA Mark shown*



*R. Tateishi*

**Issued by:** R. Tateishi, P. Eng.

## **PRODUCTS**

**CLASS 1432 01** - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breakers, Type C60, rated 0.5 to 20A, 1 pole, 277V ac max, 60Vdc max, 25 to 35A, 1-pole, 240V ac max, 60Vdc max, 0.5 to 20A, 2 pole, 480Y/277Vac max, 125V dc max, 25A to 35A, 2 pole 240Vac max, 125Vdc max and 1 to 20A 3-pole, 480Y/277Vac max, 25 to 35A, 480Y/277Vac max.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures