



Certificate of Compliance

Certificate: 1545090 **Master Contract:** 224330
Project: 80154036 **Date Issued:** 03/09/2023
Issued to: Schneider Toshiba Inverter SAS
Rue Andre Blanchet
Pacy sur Eure, Eure 27120
France
Attention: Eric Delaune

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Khalil Ouldchama*
Khalil Ouldchama

PRODUCTS

C321126 INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Miscellaneous

Solid state reduced voltage starters, open type, soft stop function is only provided with Type ATS01N2.

Models	Current	Frequency (Hz)	Phase	Power (HP max)	Voltage
Type ATS01N, Type ATSU01N	85A max continuous	50/60	1 or 3	75	line voltage, 480Vac max

Type ATS01N, ATSU01N followed by suffixes.



Certificate: 1545090

Master Contract: 224330

Project: 80154036

Date Issued: 03/09/2023

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 60947-1-13 (Second Edition) - Low-Voltage Switchgear and Controlgear - Part 1: General rules

dated July 31, 2013.

CSA C22.2 NO. 60947-4-2-14 (First Edition) (R2019) - Low-voltage switchgear and controlgear - Part 4-2: Contactors and motor-starters - AC semiconductor motor controllers and starters (Bi-national standard, with UL 60947-4-2)

dated March 21, 2014.



Certificate: 1545090


Project: 80154036

Master Contract: 224330

Date Issued: 03/09/2023

Notes:

Products certified under Class C321126 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 1545090

Master Contract: 224330

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80154036	March 09, 2023	Update of report 224330-1545090 to review contact rating of relay K1 (item 16), type SGR020F 024VDC 1AH HVASO assembled with model ATS01N112FT, following to reported (FIR) dated December 05, 2022 to address this non-conformance noted in (FC# 233897).
80094867	June 15, 2022	Addition of accepted alternates components with the same electrical rating as previous certified components, to correct some errors from previous edition (Ed.6) of report and to resolve all finding reported in FIR dated July 15, 2021, at Factory 4547915.
80071573	March 16, 2021	FIR follow-up, update to Report, Solid state reduced voltage starters, type ATS01N, to address (FC# 233897) FIR dated January 19, 2021 and addition of recognized alternate components.
80058675	November 18, 2020	Addition of alternate relay as per the FIR dated September 14, 2020. Also the addition of alternate plastic material (terminal cover), minor correction of HP rating, and capacitor model numbers.
80047850	July 21, 2020	FIR Follow-up, Schneider Toshiba Inverter SAS, FC# 233897, FIR dated May 18, 2020, Report 1545090. Evaluation as per CSA C22.2 No.60947-4- 2-14. Remove standard CSA C22.2 No.274 and CSA C22.2 No.14. Move from class number 3211-06 to 3211-26
70008672	September 24, 2014	Modification of auxiliary contact voltage rating. CSA report: 224330- 1545090. As per CSA C22.2 No.274.
2659792	September 13, 2013	Modifications under 'Markings' to change rating of auxiliary contacts Models ATS01N103 to 232 and ATS01N230 to 285
2490144	March 16, 2012	Addition of alternate accepted components for Heatsink, Case, Frame, Optoisolators, Power switching Thyristor's modules, Relays and Ignition transformer.
2317957	June 29, 2010	Change plastic on cover plate. Modification on heat sink, transformer and relays.



Certificate: 1545090

Master Contract: 224330

Project: 80154036

Date Issued: 03/09/2023

1697318	December 22, 2005	CSA report update to add new Model rated 25A, Series ATS01.
1545090	May 28, 2004	Original Certification, ATS01 Electronic progressive asynchronous motor starter (some models are previously certified under 164581-1286673).