

CCA – CENELEC Certification Agreement
 Accord de Certification du CENELEC – CENELEC – Zertifizierungs – Abkommen

STATEMENT OF TEST RESULTS

Product RESIDUAL OPERATED CIRCUIT BREAKERS WITH INTEGRAL OVERCURRENT PROTECTION

FOR HOUSEHOLD AND SIMILAR USES (RCBO's)

tested by request of SCHNEIDER ELECTRIC INDUSTRIES SAS

Electropole 31 Rue Pierre Mendès - 38050 GRENOBLE CEDEX 9 (F)

manufactured at (name and place) GEWISS PORTUGAL LDA – 4560 PENAFIEL (P)

Rating and principal characteristics 3P; 4P; 230-400V; 6000A; Type A; 10A-13A-16A-20A-25A-32A; curve B and C;

30mA (see on pages 7 and 8 of Test Report PB14S0260247-02-00)

Preliminary visit carried out by _____

Trade mark (if any) _____



Model/Type Ref. Series Acti 9 DCP N Vigi (see on page 7 of Test Report PB14S0260247-02-00)

Additional Information (if any) _____

A sample of the product has been tested and found to be in conformity with _____

EN 61009-1:2004 + A11:2008 + A12:2009 + A13:2009 + A14:2012

as shown in the test report (reference No. from PB14S0260247-02-00 to PB14S0260247-02-13)

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

20138 MILANO – Via Quintiliano, 43
 Telephone: (+39) 02-50731
 Telefax: (+39) 02-50991500
 e-mail: info@imq.it

IMQ S.p.A.

Internal ref.: Fulvio GIORGI

Date 2014-06-27

Signature, _____