

CERTIFICATE OF COMPLIANCE

Certificate Number 20180523 – E201954
Report Reference E201954 – 20000524
Issue Date 2018 MAY 23

Issued to: SCHNEIDER ELECTRIC USA, INC.
1010 Airpark Center Dr
Nashville, TN 37217 USA

**This is to certify that
representative samples of**

Switchgear Assemblies, Metal Enclosed, Low-voltage-
power Circuit-breaker Type
PowerZone 4 Metal Enclosed, Low-Voltage Power Circuit
Breaker Type, Front Accessible Switchgear employing
MASTERPACT NW & NT Circuit Breakers Continuous
Current – 1600, 2000 and 3200 amperes
Maximum Rated Voltage – 635 ac (600 nominal).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1558, "Metal-Enclosed Low-Voltage Power Circuit
Breaker Switchgear," IEEE C37.20.1, "IEEE Standard for
Metal-Enclosed Low-Voltage Power Circuit Breaker
Switchgear" and CAN/CSA-C22.2 No. 31, "Switchgear
Assemblies."

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

