

CERTIFICATE OF COMPLIANCE

Certificate Number 20140106-E363533
Report Reference E363533-20131207
Issue Date 2014-JANUARY-06

Issued to: MERLIN GERIN, DBA SCHNEIDER ELECTRIC
INDUSTRIES S A S
ELECTROPOLE/EYBENS, POWER / LV
31 RUE PIERRE MENDES FRANCE
38050 GRENOBLE CEDEX 9 FRANCE

**This is to certify that
representative samples of**

CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-
BREAKER ENCLOSURES FOR USE IN PHOTOVOLTAIC
SYSTEMS


Molded case circuit breakers PowerPact T with suffix TB
and TG rated 50A through 200A for circuit breakers; 600
Vdc for 3 poles and 1000 Vdc for 4 poles, with poles wired
in series

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 489B - Standard for Molded Case Circuit Breakers,
Molded Case Switches and Circuit Breaker Enclosure for
Use With Photovoltaic (PV) Systems

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

