



CERTIFICATE FI 30539

Our Ref. 293994

Product Terminals, others

Type S1B96391
S1B96570

Trade mark Schneider Electric

Certificate Holder Schneider Electric Industries SAS
35, rue Joseph Monier, 92500 RUEIL MALMAISON,
FRANCE

Manufacturer Schneider Electric Industries SAS
35, rue Joseph Monier, 92500 RUEIL MALMAISON,
FRANCE

Technical information 250V~, 20A, IP30

Other information See Appendix

The product is certified according to the following standard(s) EN 61535:2009 + A1:2013

Validity This certificate is valid until 20 August 2023 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Directive information The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Date of issue 20 August 2018

Signature
Matti Huttunen
Certification Engineer

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 30539

Manufacturing sites

Elda-Eltra Elektrotechnika S.A
ul. Bugno 1, 78-400 SZCZECINEK,
POLAND

Additional information

The product has certificate 1811050 issued by Intertek Semko AB in accordance with the Nordic Certification Service system.



S1B96391

With screwless terminals. Rated impulse voltage 4kV. Non-readily. Rewirable installation female connector 2P+E tested with cord rigid (solid and stranded) 1,5/2,5 mm² is intended to be use together with Schneider Electric socket-outlets (dedicated for trunking systems),

S1B96570

With screw terminals. Rated impulse voltage 4kV. Non-readily. Rewirable installation female connector 2P+E tested with cord rigid (solid and stranded) and flexible 1,5/2,5 mm² is intended to be use together with Schneider Electric socket-outlets (dedicated for trunking systems)

This certificate replaces previous certificate FI 28250 A1 dated 03 June 2015. The certificate holder and manufacturer has been changed.

Our ref. no.

293994-1

MOC