




CERTIFICATE FI 30029

Our Ref. 285490-2

Product	Distribution box
Type	IMT35260
Trade mark	
Certificate Holder/ Manufacturer	Schneider Electric Industries SAS 35 rue Joseph Monier – CS 30323 FR 92500 Rueil-Malmaison FRANCE
Technical information	2,5 mm ² , 400 V~, IP3X, -15/60 °C
Other information	Flush mounting junction box for hollow walls etc, with inlets for sheathed cables, with inlets for corrugated conduits, with spouts, with cable retention, for suspension of luminaire
The product is certified according to the following standard(s)	EN 60670-1:2005 + A1:2013 EN 60670-21:2006
Validity	This certificate is valid until 14 December 2022 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.
Directive information	The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.
Date of issue	14 December 2017
Signature	SGS Fimko Ltd Sixten Lökfors Project Manager

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 30029

Manufacturing sites

Rosti Poland Sp. z.o.o
ul. Mysliwska 18
15-569 BIALYSTOK
POLAND

Additional information

For installation cables through strain relief and for flexible conduits through cut-out



Parts:
IMT35260 Box
IMT35263 Extension ring 13 mm
IMT35264 Ceiling Lid

As shown in the Test Report No:

285490-2