



Ref. Certif. No.

FR_712234/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker for overcurrent protection for household and similar installations

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendès France, Eybens
38050 GRENOBLE Cedex 9
FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendès France, Eybens
38050 GRENOBLE Cedex 9
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

iC60N

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_712234 dated 2021/09/03. Editorial correction

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015 +A1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

171846-763258-A-V01

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 21/09/2021



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 142
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
Certification Officer

IEC

TECEE

Ref. Certif. No.

FR_712234/A1

ANNEX

Name and address of the factories:

MERLIN GERIN ALES

16 Boulevard CHARLES PEGUY
30319 ALES CEDEX
FRANCE

SCHNEIDER ELECTRIC BULGARIA EOOD

Plovdiv plant
4202 RADINOVO PLOVDIV
BULGARIA


Schneider Electric India Pvt. Ltd.

Plot No - 172, Poonamallee Bye Pass Road, Poonamallee, Tamil Nadu
600056 CHENNAI
INDIA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 21/09/2021



Signature:  **Julien GAUTHIER**
Certification Officer

ANNEXE / ANNEX

Gamme/Series iC60N

Rated operational voltage U_e : (V)	1P : 230/400, 240/415 1P+N : 230, 240 2P, 3P, 4P : 400/415
Rated current I_n : (A)	B : 0.5, 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63 C : 0.5, 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63 D : 0.5, 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63
Rated frequency : (Hz)	50/60
Nature of supply :	~
Total number of poles :	1, 1+N (neutral on left), 2, 3, 4
Number of protected poles :	Tous / all
Rated insulation voltage U_i : (V)	500
Rated impulse withstand voltage U_{imp} : (V)	4000
Instantaneous tripping current :	B, C, D
Reference ambient calibration air temperature : ($^{\circ}$ C)	30
Rated short-circuit capacity I_{cn} : (A)	6000
Rated making and breaking capacity on one pole separately I_{cn1} : (A)	6000
Energy limiting class (I^2t) : according to EN 60898-1	3
Grid distance (short-circuit tests) :	45mm from 0,5A up to 40A 65mm for 50A and 63A
Protection against external influences :	Fermé / enclosed
Protection degree :	IP20
Material group :	II
Method of mounting :	panel board/distribution board, on rail
Method of electrical connection	not associated with the mechanical-mounting
Type of terminals :	pillar terminals
Nominal diameter of thread : (mm)	5,0 from 0,5A up to 25A 6,5 from 32A up to 63A
Operating means	lever



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 21/09/2021




Signature: **Julien GAUTHIER**
Certification Officer

ANNEXE / ANNEX

Ref Designation	Brand	Device Short Name	Poles Description	Rated Current	Curve Code	Ales	Plovdiv	Chennai
iC60N 1P 0,5A B	Schneider Electric	iC60N	1P	0,5	B	X	X	X
iC60N 1P 1A B	Schneider Electric	iC60N	1P	1	B	X	X	X
iC60N 1P 2A B	Schneider Electric	iC60N	1P	2	B	X	X	X
iC60N 1P 3A B	Schneider Electric	iC60N	1P	3	B	X	X	X
iC60N 1P 4A B	Schneider Electric	iC60N	1P	4	B	X	X	X
iC60N 1P 6A B	Schneider Electric	iC60N	1P	6	B	X	X	X
iC60N 1P 10A B	Schneider Electric	iC60N	1P	10	B	X	X	X
iC60N 1P 13A B	Schneider Electric	iC60N	1P	13	B	X	X	X
iC60N 1P 16A B	Schneider Electric	iC60N	1P	16	B	X	X	X
iC60N 1P 20A B	Schneider Electric	iC60N	1P	20	B	X	X	X
iC60N 1P 25A B	Schneider Electric	iC60N	1P	25	B	X	X	X
iC60N 1P 32A B	Schneider Electric	iC60N	1P	32	B	X	X	X
iC60N 1P 40A B	Schneider Electric	iC60N	1P	40	B	X	X	X
iC60N 1P 50A B	Schneider Electric	iC60N	1P	50	B	X	X	X
iC60N 1P 63A B	Schneider Electric	iC60N	1P	63	B	X	X	X
iC60N 2P 0,5A B	Schneider Electric	iC60N	2P	0,5	B	X	X	X
iC60N 2P 1A B	Schneider Electric	iC60N	2P	1	B	X	X	X
iC60N 2P 2A B	Schneider Electric	iC60N	2P	2	B	X	X	X
iC60N 2P 3A B	Schneider Electric	iC60N	2P	3	B	X	X	X
iC60N 2P 4A B	Schneider Electric	iC60N	2P	4	B	X	X	X
iC60N 2P 6A B	Schneider Electric	iC60N	2P	6	B	X	X	X
iC60N 2P 10A B	Schneider Electric	iC60N	2P	10	B	X	X	X
iC60N 2P 13A B	Schneider Electric	iC60N	2P	13	B	X	X	X
iC60N 2P 16A B	Schneider Electric	iC60N	2P	16	B	X	X	X
iC60N 2P 20A B	Schneider Electric	iC60N	2P	20	B	X	X	X
iC60N 2P 25A B	Schneider Electric	iC60N	2P	25	B	X	X	X
iC60N 2P 32A B	Schneider Electric	iC60N	2P	32	B	X	X	X
iC60N 2P 40A B	Schneider Electric	iC60N	2P	40	B	X	X	X
iC60N 2P 50A B	Schneider Electric	iC60N	2P	50	B	X	X	X
iC60N 2P 63A B	Schneider Electric	iC60N	2P	63	B	X	X	X
iC60N 3P 0,5A B	Schneider Electric	iC60N	3P	0,5	B	X	X	X
iC60N 3P 1A B	Schneider Electric	iC60N	3P	1	B	X	X	X
iC60N 3P 2A B	Schneider Electric	iC60N	3P	2	B	X	X	X
iC60N 3P 3A B	Schneider Electric	iC60N	3P	3	B	X	X	X
iC60N 3P 4A B	Schneider Electric	iC60N	3P	4	B	X	X	X
iC60N 3P 6A B	Schneider Electric	iC60N	3P	6	B	X	X	X
iC60N 3P 10A B	Schneider Electric	iC60N	3P	10	B	X	X	X
iC60N 3P 13A B	Schneider Electric	iC60N	3P	13	B	X	X	X
iC60N 3P 16A B	Schneider Electric	iC60N	3P	16	B	X	X	X
iC60N 3P 20A B	Schneider Electric	iC60N	3P	20	B	X	X	X
iC60N 3P 25A B	Schneider Electric	iC60N	3P	25	B	X	X	X
iC60N 3P 32A B	Schneider Electric	iC60N	3P	32	B	X	X	X
iC60N 3P 40A B	Schneider Electric	iC60N	3P	40	B	X	X	X



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr




Signature: **Julien GAUTHIER**
 Certification Officer

Date: 21/09/2021

Ref Designation	Brand	Device Short Name	Poles Description	Rated Current	Curve Code	Ales	Plovdiv	Chennai
iC60N 3P 50A B	Schneider Electric	iC60N	3P	50	B	X	X	X
iC60N 3P 63A B	Schneider Electric	iC60N	3P	63	B	X	X	X
iC60N 4P 0,5A B	Schneider Electric	iC60N	4P	0,5	B	X	X	X
iC60N 4P 1A B	Schneider Electric	iC60N	4P	1	B	X	X	X
iC60N 4P 2A B	Schneider Electric	iC60N	4P	2	B	X	X	X
iC60N 4P 3A B	Schneider Electric	iC60N	4P	3	B	X	X	X
iC60N 4P 4A B	Schneider Electric	iC60N	4P	4	B	X	X	X
iC60N 4P 6A B	Schneider Electric	iC60N	4P	6	B	X	X	X
iC60N 4P 10A B	Schneider Electric	iC60N	4P	10	B	X	X	X
iC60N 4P 13A B	Schneider Electric	iC60N	4P	13	B	X	X	X
iC60N 4P 16A B	Schneider Electric	iC60N	4P	16	B	X	X	X
iC60N 4P 20A B	Schneider Electric	iC60N	4P	20	B	X	X	X
iC60N 4P 25A B	Schneider Electric	iC60N	4P	25	B	X	X	X
iC60N 4P 32A B	Schneider Electric	iC60N	4P	32	B	X	X	X
iC60N 4P 40A B	Schneider Electric	iC60N	4P	40	B	X	X	X
iC60N 4P 50A B	Schneider Electric	iC60N	4P	50	B	X	X	X
iC60N 4P 63A B	Schneider Electric	iC60N	4P	63	B	X	X	X
iC60N 1PPN 0,5A B	Schneider Electric	iC60N	1P+N	0,5	B	X	X	X
iC60N 1PPN 1A B	Schneider Electric	iC60N	1P+N	1	B	X	X	X
iC60N 1PPN 2A B	Schneider Electric	iC60N	1P+N	2	B	X	X	X
iC60N 1PPN 3A B	Schneider Electric	iC60N	1P+N	3	B	X	X	X
iC60N 1PPN 4A B	Schneider Electric	iC60N	1P+N	4	B	X	X	X
iC60N 1PPN 6A B	Schneider Electric	iC60N	1P+N	6	B	X	X	X
iC60N 1PPN 10A B	Schneider Electric	iC60N	1P+N	10	B	X	X	X
iC60N 1PPN 13A B	Schneider Electric	iC60N	1P+N	13	B	X	X	X
iC60N 1PPN 16A B	Schneider Electric	iC60N	1P+N	16	B	X	X	X
iC60N 1PPN 20A B	Schneider Electric	iC60N	1P+N	20	B	X	X	X
iC60N 1PPN 25A B	Schneider Electric	iC60N	1P+N	25	B	X	X	X
iC60N 1PPN 32A B	Schneider Electric	iC60N	1P+N	32	B	X	X	X
iC60N 1PPN 40A B	Schneider Electric	iC60N	1P+N	40	B	X	X	X
iC60N 1PPN 50A B	Schneider Electric	iC60N	1P+N	50	B	X	X	X
iC60N 1PPN 63A B	Schneider Electric	iC60N	1P+N	63	B	X	X	X
iC60N 1P 0,5A C	Schneider Electric	iC60N	1P	0,5	C	X	X	X
iC60N 1P 1A C	Schneider Electric	iC60N	1P	1	C	X	X	X
iC60N 1P 2A C	Schneider Electric	iC60N	1P	2	C	X	X	X
iC60N 1P 3A C	Schneider Electric	iC60N	1P	3	C	X	X	X
iC60N 1P 4A C	Schneider Electric	iC60N	1P	4	C	X	X	X
iC60N 1P 6A C	Schneider Electric	iC60N	1P	6	C	X	X	X
iC60N 1P 10A C	Schneider Electric	iC60N	1P	10	C	X	X	X
iC60N 1P 13A C	Schneider Electric	iC60N	1P	13	C	X	X	X
iC60N 1P 16A C	Schneider Electric	iC60N	1P	16	C	X	X	X
iC60N 1P 20A C	Schneider Electric	iC60N	1P	20	C	X	X	X
iC60N 1P 25A C	Schneider Electric	iC60N	1P	25	C	X	X	X
iC60N 1P 32A C	Schneider Electric	iC60N	1P	32	C	X	X	X



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr




Signature: *Julien GAUTHIER*
 Certification Officer

Date: 21/09/2021

Ref Designation	Brand	Device Short Name	Poles Description	Rated Current	Curve Code	Ales	Plovdiv	Chennai
iC60N 1P 40A C	Schneider Electric	iC60N	1P	40	C	X	X	X
iC60N 1P 50A C	Schneider Electric	iC60N	1P	50	C	X	X	X
iC60N 1P 63A C	Schneider Electric	iC60N	1P	63	C	X	X	X
iC60N 2P 0,5A C	Schneider Electric	iC60N	2P	0,5	C	X	X	X
iC60N 2P 1A C	Schneider Electric	iC60N	2P	1	C	X	X	X
iC60N 2P 2A C	Schneider Electric	iC60N	2P	2	C	X	X	X
iC60N 2P 3A C	Schneider Electric	iC60N	2P	3	C	X	X	X
iC60N 2P 4A C	Schneider Electric	iC60N	2P	4	C	X	X	X
iC60N 2P 6A C	Schneider Electric	iC60N	2P	6	C	X	X	X
iC60N 2P 10A C	Schneider Electric	iC60N	2P	10	C	X	X	X
iC60N 2P 13A C	Schneider Electric	iC60N	2P	13	C	X	X	X
iC60N 2P 16A C	Schneider Electric	iC60N	2P	16	C	X	X	X
iC60N 2P 20A C	Schneider Electric	iC60N	2P	20	C	X	X	X
iC60N 2P 25A C	Schneider Electric	iC60N	2P	25	C	X	X	X
iC60N 2P 32A C	Schneider Electric	iC60N	2P	32	C	X	X	X
iC60N 2P 40A C	Schneider Electric	iC60N	2P	40	C	X	X	X
iC60N 2P 50A C	Schneider Electric	iC60N	2P	50	C	X	X	X
iC60N 2P 63A C	Schneider Electric	iC60N	2P	63	C	X	X	X
iC60N 3P 0,5A C	Schneider Electric	iC60N	3P	0,5	C	X	X	X
iC60N 3P 1A C	Schneider Electric	iC60N	3P	1	C	X	X	X
iC60N 3P 2A C	Schneider Electric	iC60N	3P	2	C	X	X	X
iC60N 3P 3A C	Schneider Electric	iC60N	3P	3	C	X	X	X
iC60N 3P 4A C	Schneider Electric	iC60N	3P	4	C	X	X	X
iC60N 3P 6A C	Schneider Electric	iC60N	3P	6	C	X	X	X
iC60N 3P 10A C	Schneider Electric	iC60N	3P	10	C	X	X	X
iC60N 3P 13A C	Schneider Electric	iC60N	3P	13	C	X	X	X
iC60N 3P 16A C	Schneider Electric	iC60N	3P	16	C	X	X	X
iC60N 3P 20A C	Schneider Electric	iC60N	3P	20	C	X	X	X
iC60N 3P 25A C	Schneider Electric	iC60N	3P	25	C	X	X	X
iC60N 3P 32A C	Schneider Electric	iC60N	3P	32	C	X	X	X
iC60N 3P 40A C	Schneider Electric	iC60N	3P	40	C	X	X	X
iC60N 3P 50A C	Schneider Electric	iC60N	3P	50	C	X	X	X
iC60N 3P 63A C	Schneider Electric	iC60N	3P	63	C	X	X	X
iC60N 4P 0,5A C	Schneider Electric	iC60N	4P	0,5	C	X	X	X
iC60N 4P 1A C	Schneider Electric	iC60N	4P	1	C	X	X	X
iC60N 4P 2A C	Schneider Electric	iC60N	4P	2	C	X	X	X
iC60N 4P 3A C	Schneider Electric	iC60N	4P	3	C	X	X	X
iC60N 4P 4A C	Schneider Electric	iC60N	4P	4	C	X	X	X
iC60N 4P 6A C	Schneider Electric	iC60N	4P	6	C	X	X	X
iC60N 4P 10A C	Schneider Electric	iC60N	4P	10	C	X	X	X
iC60N 4P 13A C	Schneider Electric	iC60N	4P	13	C	X	X	X
iC60N 4P 16A C	Schneider Electric	iC60N	4P	16	C	X	X	X
iC60N 4P 20A C	Schneider Electric	iC60N	4P	20	C	X	X	X
iC60N 4P 25A C	Schneider Electric	iC60N	4P	25	C	X	X	X



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Date: 21/09/2021


Signature: **Julien GAUTHIER**
 Certification Officer

Ref Designation	Brand	Device Short Name	Poles Description	Rated Current	Curve Code	Ales	Plovdiv	Chennai
iC60N 4P 32A C	Schneider Electric	iC60N	4P	32	C	X	X	X
iC60N 4P 40A C	Schneider Electric	iC60N	4P	40	C	X	X	X
iC60N 4P 50A C	Schneider Electric	iC60N	4P	50	C	X	X	X
iC60N 4P 63A C	Schneider Electric	iC60N	4P	63	C	X	X	X
iC60N 1PPN 0,5A C	Schneider Electric	iC60N	1P+N	0,5	C	X	X	X
iC60N 1PPN 1A C	Schneider Electric	iC60N	1P+N	1	C	X	X	X
iC60N 1PPN 2A C	Schneider Electric	iC60N	1P+N	2	C	X	X	X
iC60N 1PPN 3A C	Schneider Electric	iC60N	1P+N	3	C	X	X	X
iC60N 1PPN 4A C	Schneider Electric	iC60N	1P+N	4	C	X	X	X
iC60N 1PPN 6A C	Schneider Electric	iC60N	1P+N	6	C	X	X	X
iC60N 1PPN 10A C	Schneider Electric	iC60N	1P+N	10	C	X	X	X
iC60N 1PPN 13A C	Schneider Electric	iC60N	1P+N	13	C	X	X	X
iC60N 1PPN 16A C	Schneider Electric	iC60N	1P+N	16	C	X	X	X
iC60N 1PPN 20A C	Schneider Electric	iC60N	1P+N	20	C	X	X	X
iC60N 1PPN 25A C	Schneider Electric	iC60N	1P+N	25	C	X	X	X
iC60N 1PPN 32A C	Schneider Electric	iC60N	1P+N	32	C	X	X	X
iC60N 1PPN 40A C	Schneider Electric	iC60N	1P+N	40	C	X	X	X
iC60N 1PPN 50A C	Schneider Electric	iC60N	1P+N	50	C	X	X	X
iC60N 1PPN 63A C	Schneider Electric	iC60N	1P+N	63	C	X	X	X
iC60N 1P 0,5A D	Schneider Electric	iC60N	1P	0,5	D	X	X	
iC60N 1P 1A D	Schneider Electric	iC60N	1P	1	D	X	X	
iC60N 1P 2A D	Schneider Electric	iC60N	1P	2	D	X	X	
iC60N 1P 3A D	Schneider Electric	iC60N	1P	3	D	X	X	
iC60N 1P 4A D	Schneider Electric	iC60N	1P	4	D	X	X	
iC60N 1P 6A D	Schneider Electric	iC60N	1P	6	D	X	X	
iC60N 1P 10A D	Schneider Electric	iC60N	1P	10	D	X	X	
iC60N 1P 13A D	Schneider Electric	iC60N	1P	13	D	X	X	
iC60N 1P 16A D	Schneider Electric	iC60N	1P	16	D	X	X	
iC60N 1P 20A D	Schneider Electric	iC60N	1P	20	D	X	X	
iC60N 1P 25A D	Schneider Electric	iC60N	1P	25	D	X	X	
iC60N 1P 32A D	Schneider Electric	iC60N	1P	32	D	X	X	
iC60N 1P 40A D	Schneider Electric	iC60N	1P	40	D	X	X	
iC60N 1P 50A D	Schneider Electric	iC60N	1P	50	D	X	X	
iC60N 1P 63A D	Schneider Electric	iC60N	1P	63	D	X	X	
iC60N 2P 0,5A D	Schneider Electric	iC60N	2P	0,5	D	X	X	
iC60N 2P 1A D	Schneider Electric	iC60N	2P	1	D	X	X	
iC60N 2P 2A D	Schneider Electric	iC60N	2P	2	D	X	X	
iC60N 2P 3A D	Schneider Electric	iC60N	2P	3	D	X	X	
iC60N 2P 4A D	Schneider Electric	iC60N	2P	4	D	X	X	
iC60N 2P 6A D	Schneider Electric	iC60N	2P	6	D	X	X	
iC60N 2P 10A D	Schneider Electric	iC60N	2P	10	D	X	X	
iC60N 2P 13A D	Schneider Electric	iC60N	2P	13	D	X	X	
iC60N 2P 16A D	Schneider Electric	iC60N	2P	16	D	X	X	
iC60N 2P 20A D	Schneider Electric	iC60N	2P	20	D	X	X	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 21/09/2021



Signature: *Julien GAUTHIER*
 Certification Officer

Ref Designation	Brand	Device Short Name	Poles Description	Rated Current	Curve Code	Ales	Plovdiv	Chennai
iC60N 2P 25A D	Schneider Electric	iC60N	2P	25	D	X	X	
iC60N 2P 32A D	Schneider Electric	iC60N	2P	32	D	X	X	
iC60N 2P 40A D	Schneider Electric	iC60N	2P	40	D	X	X	
iC60N 2P 50A D	Schneider Electric	iC60N	2P	50	D	X	X	
iC60N 2P 63A D	Schneider Electric	iC60N	2P	63	D	X	X	
iC60N 3P 0,5A D	Schneider Electric	iC60N	3P	0,5	D	X	X	
iC60N 3P 1A D	Schneider Electric	iC60N	3P	1	D	X	X	
iC60N 3P 2A D	Schneider Electric	iC60N	3P	2	D	X	X	
iC60N 3P 3A D	Schneider Electric	iC60N	3P	3	D	X	X	
iC60N 3P 4A D	Schneider Electric	iC60N	3P	4	D	X	X	
iC60N 3P 6A D	Schneider Electric	iC60N	3P	6	D	X	X	
iC60N 3P 10A D	Schneider Electric	iC60N	3P	10	D	X	X	
iC60N 3P 13A D	Schneider Electric	iC60N	3P	13	D	X	X	
iC60N 3P 16A D	Schneider Electric	iC60N	3P	16	D	X	X	
iC60N 3P 20A D	Schneider Electric	iC60N	3P	20	D	X	X	
iC60N 3P 25A D	Schneider Electric	iC60N	3P	25	D	X	X	
iC60N 3P 32A D	Schneider Electric	iC60N	3P	32	D	X	X	
iC60N 3P 40A D	Schneider Electric	iC60N	3P	40	D	X	X	
iC60N 3P 50A D	Schneider Electric	iC60N	3P	50	D	X	X	
iC60N 3P 63A D	Schneider Electric	iC60N	3P	63	D	X	X	
iC60N 4P 0,5A D	Schneider Electric	iC60N	4P	0,5	D	X	X	
iC60N 4P 1A D	Schneider Electric	iC60N	4P	1	D	X	X	
iC60N 4P 2A D	Schneider Electric	iC60N	4P	2	D	X	X	
iC60N 4P 3A D	Schneider Electric	iC60N	4P	3	D	X	X	
iC60N 4P 4A D	Schneider Electric	iC60N	4P	4	D	X	X	
iC60N 4P 6A D	Schneider Electric	iC60N	4P	6	D	X	X	
iC60N 4P 10A D	Schneider Electric	iC60N	4P	10	D	X	X	
iC60N 4P 13A D	Schneider Electric	iC60N	4P	13	D	X	X	
iC60N 4P 16A D	Schneider Electric	iC60N	4P	16	D	X	X	
iC60N 4P 20A D	Schneider Electric	iC60N	4P	20	D	X	X	
iC60N 4P 25A D	Schneider Electric	iC60N	4P	25	D	X	X	
iC60N 4P 32A D	Schneider Electric	iC60N	4P	32	D	X	X	
iC60N 4P 40A D	Schneider Electric	iC60N	4P	40	D	X	X	
iC60N 4P 50A D	Schneider Electric	iC60N	4P	50	D	X	X	
iC60N 4P 63A D	Schneider Electric	iC60N	4P	63	D	X	X	
iC60N 1PPN 0,5A D	Schneider Electric	iC60N	1P+N	0,5	D	X	X	
iC60N 1PPN 1A D	Schneider Electric	iC60N	1P+N	1	D	X	X	
iC60N 1PPN 2A D	Schneider Electric	iC60N	1P+N	2	D	X	X	
iC60N 1PPN 3A D	Schneider Electric	iC60N	1P+N	3	D	X	X	
iC60N 1PPN 4A D	Schneider Electric	iC60N	1P+N	4	D	X	X	
iC60N 1PPN 6A D	Schneider Electric	iC60N	1P+N	6	D	X	X	
iC60N 1PPN 10A D	Schneider Electric	iC60N	1P+N	10	D	X	X	
iC60N 1PPN 13A D	Schneider Electric	iC60N	1P+N	13	D	X	X	
iC60N 1PPN 16A D	Schneider Electric	iC60N	1P+N	16	D	X	X	
iC60N 1PPN 20A D	Schneider Electric	iC60N	1P+N	20	D	X	X	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Signature: *Julien Gauthier*
Julien GAUTHIER
 Certification Officer


Date: 21/09/2021

Ref Designation	Brand	Device Short Name	Poles Description	Rated Current	Curve Code	Ales	Plovdiv	Chennai
iC60N 1PPN 25A D	Schneider Electric	iC60N	1P+N	25	D	X	X	
iC60N 1PPN 32A D	Schneider Electric	iC60N	1P+N	32	D	X	X	
iC60N 1PPN 40A D	Schneider Electric	iC60N	1P+N	40	D	X	X	
iC60N 1PPN 50A D	Schneider Electric	iC60N	1P+N	50	D	X	X	
iC60N 1PPN 63A D	Schneider Electric	iC60N	1P+N	63	D	X	X	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 21/09/2021



Signature: **Julien GAUTHIER**
 Certification Officer