



# TYPE APPROVAL CERTIFICATE

Certificate No:  
**TAA00000VK**  
Revision No:  
**1**

## This is to certify:

**That the Programmable Controller**

with type designation(s)

**Smart Relays Series Zelio Logic, Telemecanique Zelio Models SR2 & SR3**

Issued to

**Schneider Electric Automation GmbH**  
**Marktheidenfeld, Germany**

is found to comply with

**DNV rules for classification – Ships, offshore units, and high speed and light craft**

## Application :

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.**

<b>Temperature</b>	<b>B</b>
<b>Humidity</b>	<b>B</b>
<b>Vibration</b>	<b>A</b>
<b>EMC</b>	<b>A</b>
<b>Enclosure</b>	<b>A</b>

Issued at **Hamburg** on **2022-04-01**

for **DNV**

This Certificate is valid until **2027-03-31**.

DNV local station: **Augsburg**

Approval Engineer: **Dariusz Lesniewski**

.....  
**Joannis Papanuskas**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



## Product description

### Compact Smart Relays with Display

12 V DC SR2B121JD; SR2B201JD  
 24 V DC SR2A101BD; SR2B121BD; SR2B122BD; SR2A201BD; SR2B201BD; SR2B202BD  
 24 V AC SR2B121B; SR2B201B  
 100 ... 240 V AC SR2A101FU; SR2B121FU; SR2A201FU; SR2B201FU

### Compact Smart Relays without Display

24 V DC SR2D101BD; SR2E121BD; SR2D201BD; SR2E201BD  
 24 V AC SR2E121B; SR2E201B  
 100 ... 240 V AC SR2D101FU; SR2E121FU; SR2D201FU; SR2E201FU

Firmware Version: V Z2DC27\_4\_03\_1\_2\_012345----.bz2 and Z2DC2a\_4\_03\_1\_1\_012345----.bz2

### Modular Smart Relays with Display

12 V DC SR3B261JD  
 24 V DC SR3B101BD; SR3B102BD; SR3B261BD; SR3B262BD  
 24 V AC SR3B101B; SR3B261B  
 100 ... 240 V AC SR3B101FU; SR3B261FU

Analogue I/O extension modules 4 I/Os SR3XT43BD

### Discrete I/O Extension Module SR3XT

12 V DC for SR3B261JD SR3XT61JD; SR3XT101JD; SR3XT141JD  
 24 V DC for SR3B...BD SR3XT61BD; SR3XT101BD; SR3XT141BD  
 24 V AC for SR3B...B SR3XT61B; SR3XT101B; SR3XT141B  
 100 ... 240 V AC for SR3B...FU SR3XT61FU; SR3XT101FU; SR3XT141FU

Modbus network communication module SR3NET01BD

Modbus network slave communication module SR3MBU01BD

Memory Cartridge SR2MEM01; SR2MEM02

Connecting Cable; Interface SR2CBL01; SR2USB01; SR2CBL06

### Inputs:

Discrete DC Input Ratings (I1...IA & ICH...IR) SR.....JD 12 V DC / 4 mA; SR.....BD 24 V DC / 4 mA  
 Discrete or Analog DC Input Ratings (IB...IG) SR.....JD 12 V DC / 4 mA; SR.....BD 24 V DC / 4 mA  
 Analog DC Input Ratings SR.....JD 0...10 V or 0...12 V  
 SR.....BD 0...10 V or 0...24 V  
 Analog DC Input Ratings (IH, IJ & Pt) IH, IJ 0...10 V DC, 0...20 mA; Pt -25°C ... +125°C  
 Discrete AC Input Ratings SR.....B 24 V AC / 4.4 mA;  
 SR.....FU 100 ... 240 V AC / 0.6 mA

### Outputs:

Relay Output Ratings 8x Outputs lth 8A SR2... / SR3B101.. / SR3XT61.. / SR3XT101..  
 8x Outputs lth 8A +2x Outputs lth 5A SR3B261..  
 4x Outputs lth 8A +2x Outputs lth 5A SR3XT141..  
 DC12 24 V DC / 1.5 A; DC13 24 V DC / 0.6 A  
 AC12 230 V AC / 1.5 A; AC15 230 V AC / 0.9 A  
 Transistor Output Ratings 24 V DC / 0.5 A SR.B..2BD

Supplies:		
Supply Ratings	12 V DC	SR2B121JD 120 mA; SR2B201JD 200 mA; SR3B261JD 250 mA, 400 mA with extension
Supply Ratings	24 V DC	SR2.1.1BD 100 mA; SR2B122BD 100 mA; SR2.201BD 100 mA; SR2B202BD 100 mA; SR3B101BD 100 mA with extension; SR3B102BD 50 mA, 160 mA with extension; SR3B261BD 190 mA, 300 mA with extension; SR3B262BD 70 mA, 180 mA with extension
Supply Ratings	24 V AC	SR2B121B 145 mA; SR2.201B 233 mA; SR3B101B 160 mA, 280 mA with extension; SR3B261B 280 mA, 415 mA with extension
Supply Ratings	100...240 V AC	SR2.101FU, SR2.121FU 80-30 mA; SR2.201FU 100-50 mA; SR3B101FU 80-30 mA, 80-40 mA with extension; SR3B261FU 100-50 mA, 80-60 mA with extension

### Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

#### Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

#### Software control

All changes in software are to be recorded as long as the system is in use on board. Documentation of major changes is to be forwarded to DNV for evaluation and approval before implemented on board. Certification of modified functionality may be required for the particular vessel.

### Type Approval documentation

#### Test reports:

1505568	dated 09-11-2005
EMC RC-03-40777-A	dated 28-01-2004
RC-03-40134-1-A	dated 25-03-2003
No. 030212	dated 20-05-2003
No. 030395 and No. 040276	dated 20-02-2006
NE110 015P05001 V 00.02	dated 29-11-2005
NE110 023P05000 V 00	dated 21-03-2005
NE112 031P05000 V 00	dated 30-09-2005
NE112 033P05000 V 00.00	dated 20-04-2006
NE112 034P05000 V 00.00	dated 31-31-2006
R-032-C45-07-100812-1-A-FL-PH	dated 27-03-2007
RCE-100-20-105798-1-A (01)	dated 01-07-2021
RME-100-20-105545-1-A (01)	dated 24-03-2021

#### Documents:

Qualification Plan	dated 20-02-2006
Zelio CD Qualif. GL Zelio	
Data sheet: HF118F issue 2020 Rev. 1.00	
Data sheet: HF41F issue 2020 Rev. 1.00	
Type approval assessment report issued at Augsburg on 2022-02-10	

### Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021.

### Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

### **Periodical assessment**

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE