

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker

Name and address of the applicant

Schneider Electric Industries SAS
31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE
CEDEX 9
FRANCE

Name and address of the manufacturer

Schneider Electric Industries SAS
31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE
CEDEX 9
FRANCE

Name and address of the factory

Schneider Electric France
6-8 rue du Bailly, 21078 DIJON CEDEX
FRANCE

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Ue 690V, In 13 up to 65A and In 73 up to 80A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Stage 2

Model / Type Ref.

GV3 P; GV3 L

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007
IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-2:2016
IEC 60947-4-1:2009
IEC 60947-4-1:2009/AMD1:2012

As shown in the Test Report Ref. No. which forms part of this Certificate

188115-CC2-1; 234365-TL3-2; 234365-TL3-3; 249419-TL3-4

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-04-13

Signature:

J. Richter