



CB TEST CERTIFICATE

Ref. Certificate No.

NL-20380

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Adaptor provided with SPD		
Applicant:	American Power Conversion Holding Inc. Taiwan Branch	3F. No. 205. Sec. 3. Beishin Rd. Shindian City, TAIPEI	Taiwan
Manufacturer:	American Power Conversion Holding Inc. Taiwan Branch	3F. No. 205. Sec. 3. Beishin Rd. Shindian City, TAIPEI	Taiwan
Factory: nb: Additional factory information on page 2	Dongguan Quan Sheng Electric Co., Ltd.	Hou-Chieh Town, Dongguan City, Guangdong Province	China
Rating and principal characteristics:	16 A - 250 V~ Uoc 6 kV, Up 1,4 kV		
Trade mark (if any):	APC		
Model/Type reference:	P1-..		
Additional information:	body of thermoplastic material provided with an incorporated AC Surge Protective Device		
Sample of product tested to be in conformity with IEC:	60884-1(ed.3);am1 60884-2-5(ed.1) 61643-1(ed.2)	National differences: NL	
Test Report Ref. No:	2124967.50A/50B/50C-DCC (46,36 and 75 pages)		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2011-05-17



DEKRA Certification is former KEMA Quality



IEC SYSTEM FOR CONFORMITY TESTING TO
STANDARDS FOR SAFETY OF ELECTRICAL
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-20380

American Power Conversion
Lot 9, Block 3, Phase II, PEZA, Rosario, Cavite 4106
Philippines

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2011-05-17

DEKRA
DEKRA Certification is
former KEMA Quality