



CB TEST CERTIFICATE

Ref. Certificate No.

NL-24428/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: DEKRA Certification B.V.
Product: Multiple portable socket-outlet provided with surge protective device

Applicant: American Power Conversion Holding Inc. Lot 1 Block 5 Phase II PEZA Rosario 4106 Cavite, Philippines

Manufacturer: American Power Conversion Holding Inc. Lot 1 Block 5 Phase II PEZA Rosario 4106 Cavite, Philippines

Factory: Dongguan Quan Sheng Electric Co., Ltd. Ju-Tang 2nd Industrial Park, 523963, Dongguan Guangdong China
nb: Additional factory information on page 2

Rating and principal characteristics: 16 A, 250 V~, (limited to 10 A by means of a circuit breaker)
T3, Uoc: 6 kV, Up: 1,4 kV

Trade mark (if any): APC

Model/Type reference: PH6....-GR, PF8....-GR

Additional information: Body of thermoplastic material, provided with an incorporated Surge Protective Device.

Sample of product tested to be in conformity with IEC: 60884-1(ed.3);am1
61643-1(ed.2)

Test Report Ref. No: 215484253A-DCC and 2154842.53B-DCC

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2012-10-01





IEC SYSTEM FOR CONFORMITY
TESTING TO STANDARDS FOR
SAFETY OF ELECTRICAL
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-24428/A1

International Precision Assemblies Inc. Plant 3 Lot 9, Block 3, 4106, Rosario Cavite, Philippines	International Precision Assemblies Inc Lot 6 Block 8, Phase II PEZA Rosario 4106 Cavite, Philippines

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
 Utrechtseweg 310
 P.O. Box 5185
 6802 ED Arnhem
 The Netherlands



Signed by: H.R.M. Barends

Date of issue: 2012-10-01