

Certificate



Certificate no.

CU 72082416 01

License Holder:

American Power Conversion Corp.
85 Rangeway Road
North Billerica MA 01862
USA

Manufacturing Plant:

American Power Conversion
(India) Pvt., Ltd.
187/3 & 188/3, Jigani
562 106 Anekal, Bangalore
India

Test report no.: USA-GW 30882994 001

Client Reference: John Coviello

Tested to: UL 1778:2005 R7.06
C22.2 No. 107.3-05 + A1:06

Certified Product: Uninterruptible Power Supply (UPS)

License Fee - Units

Model Designation: 1) SURT20KRMXLT, 2) SURT15KRMXLT,
3) SURT18KRMXLJ, 4) SURT14KRMXLJ

7

Rated Voltage: 1), 2) AC 208/240V, 50/60Hz
3), 4) AC 200V, 50/60Hz

Rated Current: 1), 3) 100A
2), 4) 80A

Protection Class: I

Output Ratings: 1), 2) AC 208/240V, 50/60Hz
3), 4) AC 200V, 50/60Hz
1) 96A, 2) 72A, 3) 90A, 4) 70A

7

Appendix: 1, 1-5

Licensed Test mark:

Signature

Date of Issue

(day/mo/yr)

26/11/2008



Martin Gagl

Dipl.-Ing. M. Gagl
QA Certification Officer