

# CERTIFICATE OF CONFORMITY



**Equipment** : UPS  
**Brand Name** : APC  
**Test Model No.** : SMT1500I, SMT1000I, SMT750I  
**Multiple Listing** : SMT1500IXXXXXXXXXX,  
SMT1000IXXXXXXXXXX,  
SMT750IXXXXXXXXXX  
(The X in above models could be 0~9, A~Z or blank for marketing differences.)  
**Applicant** : American Power Conversion Holding Inc, Taiwan Branch  
**Test Report No.** : CE990804D05

We, **Bureau Veritas Consumer Products Services (H.K.) Ltd., Taoyuan Branch**, declare that the equipment above has been tested in our facility and found compliance with the requirement limits of applicable standards. The test record, data evaluation and Equipment Under Test (EUT) configurations represented herein are true and accurate under the standards herein specified.

---

**EN 62040-2: 2006, Category C2**

---

IEC 61000-3-2: 2005 ED.3.0

---

IEC 61000-4-2: 2008 ED.2.0

---

IEC 61000-4-3: 2006+A1:2007 ED.3.0

---

IEC 61000-4-4: 2004+A1: 2010 ED.2.0

---

IEC 61000-4-5: 2005 ED.2.0

---

IEC 61000-4-6: 2008 ED.3.0

---

IEC 61000-4-8: 2009 ED.2.0

---

IEC 61000-2-2: 2002 ED.2.0

---

**Notes:** The above IEC basic standards are applied with latest version if customer has no special requirement

In accordance with the council directive 2004/108/EC

*Kenny Meng*

Kenny Meng / Assistant Manager

Sep. 24, 2010



No. 47, 14th Ling, Chia Pau Tsuen, Lin Kou Hsiang, Taipei Hsien, 244 Taiwan

Tel: 886-2-26052180 Fax: 886-2-26051924

<http://www.adt.com.tw> E-Mail: [service@adt.com.tw](mailto:service@adt.com.tw)