

CERTIFICATE OF CONFORMITY



Product : UPS
Brand : APC
Test Model : SMC3000RMI2U, SMC2000I-2U, SMC3000I, SMC2000I
Series Model : SMCXXXXXXXXXXXX (X be 0-9, A-Z or blank)
Applicant : American Power Conversion Holding Inc, Taiwan Branch
Report No. : C130628D02A R1

We, **Bureau Veritas Consumer Products Services (H.K.) Ltd., Taoyuan Branch**, declare that the equipment above has been tested in our facility and found compliance with the requirement limits of applicable standards. The test record, data evaluation and Equipment Under Test (EUT) configurations represented herein are true and accurate under the standards herein specified.


CISPR 22:2008, Class A

AS/NZS CISPR 22:2009 +A1:2010, Class A

EN 62040-2:2006 / IEC 62040-2:2005 ED. 2.0, Category C2

Note: ACMA will accept test reports to later standards where proof of compliance to the following clauses is not required to be demonstrated against:

- Immunity, harmonics and flicker tests


Kenny Meng / Assistant Manager
Nov. 15, 2017

No. 47-2, 14th Ling, Chia Pau Vil., Lin Kou Dist., New Taipei City, Taiwan (R.O.C.)

Tel: 886-2-26052180 Fax: 886-2-26051924

<http://www.bureauveritas-adt.com> E-Mail: service.adt@tw.bureauveritas.com

Cancel and replaces the Certificate No.: C130628D02AC dated Feb. 13, 2014

