

TEST CERTIFICATE

Issued to: Schneider (Beijing) Medium & Low Voltage Co., Ltd.
No.2, Liang Shui He 2nd Street, BJ Economic Technological Development Area,
Beijing 100176, P.R.China

For the product: Moulded-Case Circuit Breaker

Trade name: Schneider Electric

Type/Model: EZC100H3035

Ratings: In: 35 A, 50 / 60 Hz
Ue: 415 Vac
Icu: 36 kA
Ics: 18 kA

Manufactured by: Schneider Electric Industries SAS
38, EQI Electropole Eybens Rue Francois Quesnay
38320 EYBENS
France

Subject: Type test

Requirements: IEC 60947-2:2006, A1:2009, Clause 8.3.4 and 8.3.5

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 3302449.01.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

17 August 2011

Number: 2146808.100

DEKRA Certification B.V.



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

All testing, inspection, and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

KEMA Quality
Test Report