

KEMA Test Certificate

No. 2109851.104

Issued to: Schneider Electric Industries SAS
38 EQI Electropole Eybens
Rue Francois Quesnay
38320 EYBENS, FRANCE

For the product: Moulded case circuit breaker

Trade name: Merlin Gerin

Type/Model: EZC100H (1, 2, 3 and 4 pole)

Ratings: Ue = 550 Vac,
In = 15 A, 16 A, 20 A, 25 A, 30 A, 32 A, 40 A, 45 A, 50 A, 60 A, 63 A, 75 A, 80 A, 100 A

Manufactured by: Schneider Electric Industries SAS
38 EQI Electropole Eybens
Rue Francois Quesnay
38320 EYBENS, FRANCE

Subject: Sequence I according IEC60947-2 and tests according IACS E10: salt mist, dry heat, damp heat, cold and vibration and inclination tests


Requirements: IEC 60947-2 (3rd edition) and
IEC 60068-2-1, -2, -6, -30, -52 according IACS E10 (may 2004).

Remarks: The 1, 2 and 3 pole results have issued on march 23rd 2006, The 4 pole results have been issued on february 14th 2008 and tested according IEC 60947-2 (4th edition).

This Test Certificate is granted on account of an examination by KEMA, the results of which are laid down in a confidential file no. 2109851.02, dated March 25, 2008.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA

KEMA Quality B.V.
Arnhem, March 25, 2008



H.L. Schendstok
Certification Manager

©Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands
T +31 26 3 56 20 00 F +31 26 3 52 58 00 contact@kema.com www.kema.com Registered Arnhem 09085396

Experience you can trust.