

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Incorporated Surge Protective Device for signalling networks
Name and address of the applicant	American Power Conversion Holding Inc. 3F. No. 205. Sec. 3, Beixin Road., Xindian District, New Taipei City 231 Taiwan
Name and address of the manufacturer	Dongguan Quan Sheng Electric Co., Ltd. Ju-Tang 2nd Industrial Park, 523963, Dongguan, Guangdong China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Dongguan Quan Sheng Electric Co., Ltd. Ju-Tang 2nd Industrial Park, 523963, Dongguan, Guangdong China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Uc: 48 Vdc
Trademark (if any)	APC by Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	D6
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-21:2000, IEC 61643-21:2000/AMD1:2008, IEC 61643-21:2000/AMD2:2012 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6015430.52

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

