

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	Surge Protective Device, incorporated in multiple portable socket-outlets
Name and address of the Applicant Nom et adresse du demandeur	American Power Conversion Holding Inc. 3F. No. 205. Sec. 3, Beixin Road., Xindian District, New Taipei City 231 Taiwan
Name and address of the manufacturer Nom et adresse du fabricant	Dongguan Quan Sheng Electric Co., Ltd. Ju-Tang 2nd Industrial Park, 523963, Dongguan, Guangdong China
Name and address of the factory Nom et adresse de l'usine	Dongguan Quan Sheng Electric Co., Ltd. Ju-Tang 2nd Industrial Park, 523963, Dongguan, Guangdong China
Rating and principal characteristics Valeurs nominales et caractéristiques principales	Uc: 250 V~; IL:13A; Type 3; Uoc: 6 kV; Up: 1,5 kV
Trademark (if any) Marque de fabrique (si elle existe)	APC by Schneider Electric
Type of manufacturer's Testing Laboratories used Type de programme de laboratoire d'essais constructeur	
Model / Type Ref. Réf. de type	SBA6_REV:A incorporated in PM6.-UK and PM8.-UK Series (see also pages 103 to 104 of report 3167197.53)
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)	
A sample of product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et été considéré conforme à la CEI	61643-11(ed.1)
National differences / Comments Les différences nationales / Commentaires	EU Group Differences, EU Special National Conditions
As shown in the test report Ref. No. which forms part of this certificate Comme indiqué dans le rapport d'essais numéro de référence qui constitue partie de ce certificat	3167197.53

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

 DEKRA Certification B.V.
 Meander 1051, 6825 MJ
 Arnhem
 The Netherlands


Date: 2015-08-13

Signature: C.Lin

