

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Surge Protective Device, incorporated in plug-in adaptors
Name and address of the applicant	American Power Conversion Holding Inc. 3F. No. 205. Sec. 3, Beixin Road., Xindian District, New Taipei City 231 Taiwan
Name and address of the manufacturer	Dongguan Quan Sheng Electric Co., Ltd. Ju-Tang 2nd Industrial Park, 523963, Dongguan, Guangdong, China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Dongguan Quan Sheng Electric Co., Ltd. Ju-Tang 2nd Industrial Park, 523963, Dongguan, Guangdong, China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Uc: 250 V~; IL: 16A, Type 3; Uoc: 6 kV; Up: 1,6 kV
Trademark (if any)	APC by Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	SBA108 REV:A0 incorporated in PM1W-.. Series (see also page 99 of report 3169139.53)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 National differences: EU Group Differences, EU Special National Conditions
As shown in the Test Report Ref. No. which forms part of this Certificate	3169139.53

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

