



EC DECLARATION OF CONFORMITY

The undersigned, representing the following manufacturer

Manufacturer	SCHNEIDER ELECTRIC IT CORPORATION
Address	801 CORPORATE CENTRE DR O'Fallon MO 63368 United States
Authorized representative	Schneider Electric IT Logistics Europe Limited
Address	City East Business Park, Ballybrit, Galway, Ireland

Herewith declares that the products

Trademark:	Schneider Electric
Name, Type:	Air-Cooled Direct Expansion Computer Room Air Conditioner
Models:	ACRD602, ACRD602P
Year of CE marking:	2016

To which this declaration refers, conform to the following applicable European Directives:

Machinery Directive	2006/42/EC
Low Voltage Directive	2014/35/EU
Electromagnetic Compatibility Directive	2014/30/EU

For areas where those applicable and according to standards:

EN 60335-1:2012/AC:2014	Household and similar electrical appliances -Safety -Part 1: General requirements
EN 60335-2-40: 2003/A13:2012/AC:2013	Household and similar electrical appliances – Safety –Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers
EN 55022:2010	Information technology equipment -Radio disturbance characteristics - Limits and methods of measurement
EN 55022:2010/AC:2011	Information technology equipment — Immunity characteristics — Limits and methods of measurement
EN 55024:2010	Information technology equipment — Immunity characteristics — Limits and methods of measurement
EN 61000-3-11:2000	Electromagnetic compatibility (EMC) –Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current ≤75 A and subject to conditional connection
EN 61000-3-12:2011	Electromagnetic compatibility (EMC) –Part 3-12: Limits – Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current >16 A and ≤75 A per phase
IEC 61000-4-34:2009	Electromagnetic compatibility(EMC) — Part 3-34:Testing and measurement techniques-Voltage dips, short interruptions and voltage variations immunity tests for equipment with mains current more than 16A per phase

Through their design and construction meet the requirements of the European Directives and applicable standards listed above when installed and used in accordance with the instructions contained in the product documentation.

Date:	12 May 2016
Name:	Edel Sexton
Title:	Director, Schneider Electric IT Logistics Europe Limited
Place:	Galway, Ireland