



Certificate of Compliance

Certificate: 1231849 **Master Contract:** 164581
Project: 80166207 **Date Issued:** 04/21/2023
Issued to: Telemecanique/Schneider Electric Industries SAS
31 rue Pierre Mendes-France
Eybens, Isere 38320
France
Attention: Sven Salenbacher

The products listed below are eligible to bear the CSA Mark shown



Issued by: Jean-Claude Chow
Jean-Claude Chow

PRODUCTS

C321103 INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Auxiliary contact units, Cat. Nos. LA1 DX20, DX11, DX02, DY20, DZ31, DZ40, for use with motor controllers LC1-D, LP1-D, and auxiliary devices CA2-D, CA3-D.

Models	Contact Rating
LA1 DX20, DX11, DX02, DY20, DZ31, DZ40	Standard contacts: A600, Q600
	Protected contacts: 0.1A, 125V ac / 30V dc, for LA1 DY; 1A, 125V ac / 30V dc, for LA1 DX, DZ

Note: Open type devices are Certified as components of other equipment where the suitability of the combination is determined by CSA Group.



Certificate: 1231849

Project: 80166207

Master Contract: 164581

Date Issued: 04/21/2023

APPLICABLE REQUIREMENTS

CSA C22.2 NO. 14-18 - Industrial control equipment

Update No. 1 - June 2022



Certificate: 1231849


Project: 80166207

Master Contract: 164581

Date Issued: 04/21/2023

Notes:

Products certified under Class C321103 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 1231849

Master Contract: 164581

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80166207	April 21, 2023	Update report to CSA C22.2 No. 14-18, according to Industrial Control Equipment - Cert. Notice No. 60 & Informs No. 78 (Update No. 1).
2454741	September 08, 2011	Update the daily frequency of the factory test.
2067253	August 15, 2008	Add alternate miniature switch and alternate plastic material. Update report to CSA C22.2 No. 14-05 as per Cert. Notice - Industrial Control Equipment No. 17.,
1231849	August 08, 2001	Addition of version LA1DX11 and DX02. Report 164581-1231849 supersedes report LR 43364-45.
LR 43364-140	February 24, 1998	Alternate plastic material and alternate contact size.
LR 43364-45	February 05, 1991	Auxiliary contact units Types LA1DX., DY., DZ. Report 43364-45 is superseded by report 164581-1231849.