

产品认证证书

II型自愿认证

证书编号: CQC2004010304117714

发证日期: 2023年03月21日

有效期至: 2032年01月25日

委托人名称 及注册地址	上海施耐德工业控制有限公司 上海市普陀区绥德路 629 号
制造商名称 及注册地址	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
生产企业名称 及生产地址	PT. Schneider Electric Manufacturing Batam Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk – Batam, Indonesia
产品名称和系列、 规格、型号	辅助触头模块 LA1KN Uimp: 8kV;Ui:690V;AC-15:Ue/Ie:120V/6A,690V/1.04A;DC-13:Ue/Ie:125V/0.55A,600V/0.1A;Ith: 10A;防护等级: / (IP20 仅从正面);型号解释请见附件
产品标准和技术要求	GB/T 14048.5-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月24日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

郑泉

谢肇煦



中国质量认证中心

产品认证证书

II型自愿认证

证书编号: CQC2004010304117714

第 1 页 / 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

型号解释:

LA1KN I	22 II	6 III	S310 IV
I	产品基本型号: LA1KN 辅助触头模块		
II	触头排列方式: 20: 2NO 02: 2NC 11: 1NO+1NC 40: 4NO 31: 3NO+1NC 22: 2NO+2NC 13: 1NO+3NC 04: 4NC		
III	接线方式: 空白: 螺钉夹头 6: 用于环型接线件		
IV	后缀: 空白: 标准产品 S310: 用于指定用户 M: 按照特殊客户触头接线端子标志的序号		

LA1KN I	22 II	6 III	S310 IV
I-	Product basic designation: LA1KN auxiliary contact block		
II-	Contact arrangements: 20: 2NO 02: 2NC 11: 1NO+1NC 40: 4NO 31: 3NO+1NC 22: 2NO+2NC 13: 1NO+3NC 04: 4NC		
III-	Type of connection: Blank: clamps and screws. 6: for ring lugs.		
IV-	Specification code Blank: standard product S310: For specific customer M: sequence number of terminals marking for special customer		



中国质量认证中心