

IEC**IECEE**

®

™

Ref. Certif. No.

CN52918-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Electric Industries S. A.
ZAC Le Village Le Vaudreuil - 27100 - France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui: 690V;Uimp=8kV; Ith: 10A; Ue/Ie: AC-15: 120V/6A,
690V/1.04A; DC-13: 125V/0.55A, 600V/0.1A;IP20

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LAIKN;

Additional information (if necessary may also be reported on page 2)

The latest CB certificate No. is CN52918, dated 2021-03-01. The M1 modification is to add product type with M.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2020CQC-095390-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Apr.18,2023

Signature:

Xie ZhaoXu

CB 0071782