

IEC**IECEE**

®

™

Ref. Certif. No.

CN52921-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Electric Industries S.A.
20 rue de la Croix blanche - 86361 - Chasseneuil de Poitou –
France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui:690V;Uimp:6kV;Ith: 10A; AC-15:Ue/Ie:120V/6A,
690V/1.04A; DC-13:Ue/Ie:125V/0.55A, 600V/0.1A; IP20
(except for contact block without terminal cover : IP00)

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LADN,LADC;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN52921, dated 2021-03-01.
The M1 modification is to add type LADC.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-95404-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jul.01,2022

Signature:

Xie ZhaoXu

CB 0067205