



Ref. Certif. No.

CN29809

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

AC Contactor

Name and address of the applicant
Nom et adresse du demandeurSchneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference
& Exhibition Center, No 546 Luoyu Road, Donghu Hi-Tech
Development Zone, Wuhan, Hubei Province, P.R.China
Schneider Electric Manufacturing (Wuhan) Co., Ltd.Name and address of the manufacturer
Nom et adresse du fabricantRoom 807, 8F, Phase II Wuhan Science & Technology Conference
& Exhibition Center, No.546 Luoyu Road, Donghu Hi-Tech
Development Zone, Wuhan, Hubei Province, P.R.China
Schneider Electric Manufacturing (Wuhan) Co., Ltd.Name and address of the factory
Nome et adresse de l'usineNo.1 3rd Fozuling Road, Donghu New&High Tech Development
Zone, Wuhan, Hubei Province, P.R.ChinaNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.
Ref. De typeLC1E06..., LC1E06...N, LC1E09..., LC1E09...N,
LC1E12...LC1E12...N, LC1E18..., LC1E18...NAdditional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

PUBLICATION

EDITION

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60947-4-1:2009(3rd Edition)+A1:2012, IEC 60947-
1:2007(5th Edition)+A1:2010As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2013CQC-056231, C009-CB2012CQC-042546

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

CHINA QUALITY CERTIFICATION CENTRE

Date: 2014-03-20

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn

CB 0024941

LC1E06..., LC1E06...N, LC1E09..., LC1E09...N, LC1E12...,
LC1E12...N, LC1E18..., LC1E18...N

Ui: 690V;

LC1 E06...N:

Ith: 20A;

AC-3: Ue/Ie: 220V/230V/6A, 380V/6A, 660V/4.8A;

AC-4: Ue/Ie: 220V/230V/5A, 380V/5A, 660V/4A;

LC1 E06...:

Ith: 20A;

AC-3: Ue/Ie: 220V/230V/6A, 380V/6A, 400V/415V/4.9A;

AC-4: Ue/Ie: 220V/230V/5A, 380V/5A, 400V/415V/4.1A;

LC1 E09...N:

Ith: 20A;

AC-3: Ue/Ie: 220V/230V/9A, 380V/9A, 660V/6.6A;

AC-4: Ue/Ie: 220V/230V/7.5A, 380V/7.5A, 660V/5.5A;

LC1 E09...:

Ith: 25A;

AC-3: Ue/Ie: 220V/230V/9A, 380V/9A, 400V/415V/8.5A;

AC-4: Ue/Ie: 220V/230V/7.5A, 380V/7.5A, 400V/415V/7.1A;

LC1 E12...N:

Ith: 25A;

AC-3: Ue/Ie: 220V/230V/12A, 380V/12A, 660V/6.9A;

AC-4: Ue/Ie: 220V/230V/10A, 380V/10A, 660V/5.8A;

LC1 E12...:

Ith: 25A;

AC-3: Ue/Ie: 220V/230V/12A, 380V/12A, 400V/415V/11.5A;

AC-4: Ue/Ie: 220V/230V/10A, 380V/10A, 400V/415V/9.6A;

LC1 E18...N:

Ith: 25A;

AC-3: Ue/Ie: 220V/230V/18A, 380V/18A, 660V/11.5A;

AC-4: Ue/Ie: 220V/230V/15A, 380V/15A, 660V/9.6A;

LC1 E18...:

Ith: 32A;

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2014-3-20

Signature:



Wang Kejiao

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

CN29809

AC-3: U_e/I_e : 220V/230V/18A, 380V/18A, 400V/415V/15.5A;
AC-4: U_e/I_e : 220V/230V/15A, 380V/15A, 400V/415V/13A;
 U_s : AC24V, 36V, 48V, 110V, 220V, 240V, 380V, 415V, 440V 50Hz;
AC24V, 110V, 220V, 380V, 440V 60Hz; AC24V, 48V, 110V, 220V,
380V 50/60Hz;
3P;
IP20
Auxiliary Circuits (body contact):
1NO,1NC
 U_i :690V
 I_{th} : 10A;
 U_e/I_e : AC-15: 380V/1.3A, 660V/0.75A;
DC-13: 220V/0.3A

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2014-3-20

Signature:



Wang Kejiao