



# 中国国家强制性产品认证证书

证书编号: 2013010304591003

## 委托人名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 生产者(制造商)名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 生产企业名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 产品名称和系列、规格、型号

交流接触器

LC1E120...N, LC1E160...N, LC1E120..., LC1E160...;详见附件

## 产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2013年10月17日

有效期至: 2018年01月10日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2013年01月10日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0786378



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2013010304591003

## NAME AND ADDRESS OF THE APPLICANT

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suidu Road, Putuo District, Shanghai, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suidu Road, Putuo District, Shanghai, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suidu Road, Putuo District, Shanghai, P.R.China

## NAME, MODEL AND SPECIFICATION

AC Contactor

LC1E120...N, LC1E160...N, LC1E120..., LC1E160...,See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Oct.17,2013      Date of expiry: Jan.10,2018

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jan.10,2013

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 0786378



# 中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2013010304591003

纸号: 786378

LC1E120...N, LC1E160...N, LC1E120... LC1E160...; 型号解释详见附录;

Ui: 690V;

LC1E120...N, LC1E120...

Ith: 150A;

AC-3: Ue/Ie: 220V/230V/120A, 380V/400V/120A, 415V/440V/120A, 660V/690V/85.4A;

AC-4: Ue/Ie: 220V/230V/100A, 380V/400V/100A, 415V/440V/100A, 660V/690V/71.2A;

LC1E160...N, LC1E160...

Ith: 200A;

AC-3: Ue/Ie: 220V/230V/160A, 380V/400V/160A, 415V/440V/160A, 660V/690V/107.8A;

AC-4: Ue/Ie: 220V/230V/133.4A, 380V/400V/133.4A, 415V/440V/133.4A,

660V/690V/89.9A

Us: AC24V, 48V, 110V, 220V, 240V, 380V, 415V, 440V 50Hz;

AC24V, 110V, 220V, 380V, 440V 60Hz,

极数: 3P;

配用的辅助触头: (本体)

1NC1NO;

Ith: 8A;

Ue/Ie: AC-15: 380V/1.3A, 660V/0.75A;

DC-13: 220V/0.3A

型号的解释:

LC1E	120	M5	N
I	II	III	IV

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2013010304591003

纸号: 786378

I	产品基本型号
II	产品规格: 120/160
III	线圈电压代码 B5: 24 V 50Hz            B6: 24V 60Hz E5: 48 V 50Hz F5: 110V 50Hz          F6: 110V 60Hz M5: 220V 50Hz          M6: 220V 60Hz U5: 240V 50Hz Q5: 380V 50Hz          Q6: 380V 60Hz N5: 415V 50Hz R5: 440V 50Hz          R6: 440V 60Hz
IV	N: 中国销售接触器 空白: 出口接触器

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

