



中国国家强制性产品认证证书

证书编号: 2012010304572739

委托人名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖开发区珞瑜路546号科技会展中心二期8楼807室

生产者(制造商)名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖开发区珞瑜路546号科技会展中心二期8楼807室

生产企业名称、地址

施耐德电气制造(武汉)有限公司
湖北省武汉市东湖新技术开发区佛祖岭三路一号

产品名称和系列、规格、型号

交流接触器

LC1E25...N, LC1E25...; 详见参数附件

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2014年03月12日 有效期至: 2017年10月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年10月09日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0896312



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010304572739

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference & Exhibition
Center, No.546 Luoyu Road, Donghu Hi-Tech Development Zone, Wuhan, Hubei
Province, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
Room 807, 8F, Phase II Wuhan Science & Technology Conference & Exhibition
Center, No.546 Luoyu Road, Donghu Hi-Tech Development Zone, Wuhan, Hubei
Province, P. R. China

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan,
Hubei Province, P. R. China

NAME, MODEL AND SPECIFICATION

AC Contactor

LC1E25...N, LC1E25... See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-01C-011:2007).

Date of issue: Mar.12,2014 Date of expiry: Oct.09,2017

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Oct.09,2012

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0896312



中国国家强制性产品认证证书

附录:

第 1 页 共 4 页

证书编号: 2012010304572739

纸号: 896312

LC1E25...N; LC1E25...

Ui: 690V;

LC1E25...N:

Ith: 32A;

AC-3: Ue/Ie: 220V/230V/25A, 380V/25A, 660V/16.5A;

AC-4: Ue/Ie: 220V/230V/20.9A, 380V/20.9A, 660V/13.8A;

LC1E25...:

Ith: 36A;

AC-3: Ue/Ie: 220V/230V/25A, 380V/25A, 400V/415V/22A;

AC-4: Ue/Ie: 220V/230V/20.9A, 380V/20.9A, 400V/415V/18.4A;

Us: 50Hz: 24V/36V/48V/110V/220V/240V/380V/415V/440V,

60Hz: 24V/110V/220V/380V/440V;

50/60Hz: 24V/48V/110V/220V/380V

极数: 3P;

IP20;

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 4 页

证书编号: 2012010304572739

纸号: 896312

配用的辅助触头: (本体)

1NC, 1NO;

Ith: 10A;

Ue/le: AC-15: 380V/1.3A, 660V/0.75A;

DC-13: 220V/0.3A;

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 4 页

证书编号: 2012010304572739

纸号: 896312

型号的解释:

LCIE	25	10	M	S	N
I	II	III	IV	V	VI

I	交流接触器基本型号: LCIE 交流接触器经济型基本型号
II	产品规格 25
III	辅助触头类型 10: 1NO 01: 1NC
IV	线圈电压代码 见表 2
V	线圈频率代码(见表 2) 5: 50Hz 6: 60Hz 7: 50/60Hz
VI	N: 中国制造, 国内销售产品 空白: 出口产品 注: 国内销售产品和出口产品的产品结构完全相同

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 4 页 共 4 页

证书编号: 2012010304572739

纸号: 896312

型号的解释: (续)

表 2

代码	电压-频率
B5	24V-AC50Hz
CC5	36V-AC50Hz
E5	48V- AC50Hz
F5	110V- AC50Hz
M5	220V- AC50Hz
U5	240V- AC50Hz
Q5	380V- AC50Hz
N5	415V- AC50Hz
R5	440V- AC50Hz
B6	24V-AC60Hz
F6	110V-AC60Hz
M6	220V-AC60Hz
Q6	380V-AC60Hz
R6	440V-AC60Hz
B7	24V-AC50/60Hz
E7	48V- AC50/60Hz
F7	110V- AC50/60Hz
M7	220V- AC50/60Hz
Q7	380V- AC50/60Hz

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

