



Ref. Certif. No.

CN29807-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

AC Contactor

Name and address of the applicant
Nom et adresse du demandeurSchneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone,
Wuhan, P.R.ChinaName and address of the manufacturer
Nom et adresse du fabricantSchneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone,
Wuhan, P.R.ChinaName and address of the factory
Nome et adresse de l'usineSchneider Electric Manufacturing (Wuhan) Co., Ltd.
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone,
Wuhan, P.R.ChinaNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usinem, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.
Ref. De type

LC1 E32..., LC1 E32...N, LC1N32, LC1 E38..., LC1 E38...N, LC1 N38

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)The original CB is CN29807,dated 2014-03-20. The M1 certificate has be
en issued due to adding model type and changing the name of applicant.PI
ease see test report for details.

PUBLICATION

EDITION

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60947-4-1:2009(3rd Edition)+A1:2012, IEC 60947-1:2007(5th
Edition)+A1:2010As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2013CQC-056229-M1

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

CHINA QUALITY CERTIFICATION CENTRE

Date: 2017-02-07

Signature:

Wang Kejiao



Ref. Certif. No.

CN29807-M1

LC1 E32..., LC1 E32...N, LC1N32, LC1 E38..., LC1 E38...N, LC1 N38

Ui: 690V;

LC1 E32...N, LC1N32:

Ith: 40A;

AC-3: Ue/Ie: 220V/230V/32A, 380V/32A, 660V/20.2A;

AC-4: Ue/Ie: 220V/230V/26.7A, 380V/26.7A, 660V/16.9A;

LC1 E32...:

Ith: 50A;

AC-3: Ue/Ie: 220V/230V/32A, 380V/32A, 400V/415V/29A;

AC-4: Ue/Ie: 220V/230V/26.7A, 380V/26.7A, 400V/415V/24.2A;

LC1 E38...N, LC1N38:

Ith: 40A;

AC-3: Ue/Ie: 220V/230V/38A, 380V/38A, 660V/20.2A;

AC-4: Ue/Ie: 220V/230V/31.7A, 380V/31.7A, 660V/16.9A;

LC1 E38...:

Ith: 50A;

AC-3: Ue/Ie: 220V/230V/38A, 380V/38A, 400V/415V/35A;

AC-4: Ue/Ie: 220V/230V/31.7A, 380V/31.7A, 400V/415V/29.2A;

Us: AC24V, 36V, 48V, 110V, 220V, 240V, 380V, 415V, 440V 50Hz;

AC24V, 110V, 220V, 380V, 440V 60Hz;

AC24V, 48V, 110V, 220V, 230V, 380V 50/60Hz;

3P;

IP20;

Auxiliary Circuits (body contact):

1NC, 1NC1NO, 1NO;

Ui: 690V;

Ith: 10A;

Additional information (if necessary)

Information complémentaire (si nécessaire)

2017-02-07

Date:

Signature:

Wang Kejiao