



Ref. Certif. No.

CN30476-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

AC contactor

Name and address of the applicant
Nom et adresse du demandeur

Schneider Shanghai Industrial Control Co.,Ltd.
629 Sui De Road, Pu Tuo District, Shanghai, P.R.C

Name and address of the manufacturer
Nom et adresse du fabricant

Schneider Shanghai Industrial Control Co.,Ltd.
629 Sui De Road, Pu Tuo District, Shanghai, P.R.C

Name and address of the factory
Nome et adresse de l'usine

Schneider Shanghai Industrial Control Co.,Ltd.
629 Sui De Road, Pu Tuo District, Shanghai, P.R.C

Note: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usinem, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.
Ref. De type

LC1E40004...N, LC1E65004...N, LC1E40008...N,
LC1E65008...N, LC1N40004...N, LC1N65004...N,
LC1N40008...N, LC1N65008...N, LC1E40004...,
LC1E65004..., LC1E40008..., LC1E65008...;

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

The original CB No. is CN30476, dated 2014-05-27. The M1
certificate has been issued due to adding model type.

PUBLICATION

EDITION

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60947-4-1:2009(3rd edition) +A1:2012, IEC 60947-
1:2007+A1:2010

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2014CQC-058116-M1

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2017-05-16

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86-10-83886666
Fax: +86-10-83886282

website
www.cqc.com.cn

CB 0039097

LC1E40004...N, LC1E65004...N, LC1E40008...N, LC1E65008...N, LC1N40004...N,
LC1N65004...N, LC1N40008...N, LC1N65008...N, LC1E40004...,
LC1E65004..., LC1E40008..., LC1E65008...

Ui:690V;

LC1E40004..., LC1N40004...N, LC1E40004...N:

Ith=60A;

AC-1: Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/60A;

AC-3: Ue/Ie: 220V/230V/380V/400V/415V/440V/40A, 660V/690V/33.3A;

AC-4: Ue/Ie: 220V/230V/380V/400V/415V/440V/33.4A, 660V/690V/27.8A;

LC1E40008..., LC1N40008...N, LC1E40008...N:

Ith=60A;

AC-1: Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/60A;

AC-3: Ue/Ie: 220V/230V/380V/400V/415V/440V/40A, 660V/690V/33.3A;

LC1E65004..., LC1N65004...N, LC1E65004...N:

Ith=80A;

AC-1: Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/80A;

AC-3: Ue/Ie: 220V/230V/380V/400V/415V/440V/63.6A, 660V/690V/40A;

AC-4: Ue/Ie: 220V/230V/380V/400V/415V/440V/53A, 660V/690V/33.4A;

LC1E65008..., LC1N65008...N, LC1E65008...N:

Ith=80A;

AC-1: Ue/Ie: 220V/230V/380V/400V/415V/440V/660V/690V/80A;

AC-3: Ue/Ie: 220V/230V/380V/400V/415V/440V/63.6A, 660V/690V/40A;

Us: AC50/60Hz: 24V, 48V, 110V, 220V, 230V, 240V, 380V, 400V, 415V;

AC50Hz(70%~130%Us): 220V, 415V

4P;

IP20

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2017-05-16

Signature:



Wang Kejiao