

IEC**IECEE
CB
SCHEME**

Ref. Certif. No.

CN30476

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

AC contactor

Name and address of the applicant
Nom et adresse du demandeurSchneider Shanghai Industrial Control Co.,Ltd.
629 Sui De Road, Pu Tuo District, Shanghai, P.R.CName and address of the manufacturer
Nom et adresse du fabricantSchneider Shanghai Industrial Control Co.,Ltd.
629 Sui De Road, Pu Tuo District, Shanghai, P.R.CName and address of the factory
Nome et adresse de l'usineSchneider Shanghai Industrial Control Co.,Ltd.
629 Sui De Road, Pu Tuo District, Shanghai, P.R.CNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

See appendix

Trademark (if any)
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.
Ref. De typeLC1E40004..., LC1E65004..., LC1E40008..., LC1E65008..., LC1E400
04...N, LC1E65004...N, LC1E40008...N, LC1E65008...NAdditional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60947-4-1:2009(3rd edition) +A1:2012, IEC 60947-1:2007+A1:2010

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2014CQC-058116

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification**CHINA QUALITY CERTIFICATION CENTRE**

Date: 2014-05-27

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn**CB 0024670**

LC1E40004..., LC1E65004..., LC1E40008..., LC1E65008...,
LC1E40004...N, LC1E65004...N, LC1E40008...N, LC1E65008...N

Ui:690V;

LC1E40004..., LC1E40004...N: Ith=60A;

AC-1: Ue/le: 220V/230V/380V/400V/415V/440V/660V/690V/60A;

AC-3: Ue/le: 220V/230V/380V/400V/415V/440V/40A,
660V/690V/33.3A;

AC-4: Ue/le: 220V/230V/380V/400V/415V/440V/33.4A,
660V/690V/27.8A;

LC1E40008..., LC1E40008...N: Ith=60A;

AC-1: Ue/le: 220V/230V/380V/400V/415V/440V/660V/690V/60A;

AC-3: Ue/le: 220V/230V/380V/400V/415V/440V/40A,
660V/690V/33.3A;

LC1E65004..., LC1E65004...N: Ith=80A;

AC-1: Ue/le: 220V/230V/380V/400V/415V/440V/660V/690V/80A;

AC-3: Ue/le: 220V/230V/380V/400V/415V/440V/63.6A,
660V/690V/40A;

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2014-05-27

Signature:



Wang Kejiao

AC-4: Ue/le: 220V/230V/380V/400V/415V/440V/53A,

660V/690V/33.4A;

LC1E65008..., LC1E65008...N: Ith=80A;

AC-1: Ue/le: 220V/230V/380V/400V/415V/440V/660V/690V/80A;

AC-3: Ue/le: 220V/230V/380V/400V/415V/440V/63.6A,

660V/690V/40A;

Us: AC50/60Hz: 24V, 48V, 110V, 220V, 230V, 240V, 380V, 400V,
415V;

AC50Hz(70%~130%Us): 220V, 415V

4P;

IP20

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2014-05-27

Signature:



Wang Kejiao