



中国国家强制性产品认证证书

证书编号: 2010010304405641

委托人名称、地址

上海施耐德工业控制有限公司
上海市普陀区绥德路629号

生产者(制造商)名称、地址

上海施耐德工业控制有限公司
上海市普陀区绥德路629号

生产企业名称、地址

上海施耐德工业控制有限公司
上海市普陀区绥德路629号

产品名称和系列、规格、型号

交流接触器

LC1 E80...N, LC1 E95...N, LC1E80..., LC1E95...; 详见参数附件

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年03月18日

有效期至: 2020年03月18日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2010年05月11日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1111048



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2010010304405641

NAME AND ADDRESS OF THE APPLICANT

Schneider Shanghai Industrial Control Co.,Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Shanghai Industrial Control Co.,Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

NAME AND ADDRESS OF THE FACTORY

Schneider Shanghai Industrial Control Co.,Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

NAME, MODEL AND SPECIFICATION

AC contactor

LC1 E80...N,LC1 E95...N;LC1E80...,LC1E95...;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Mar.18,2015 Date of expiry: Mar.18,2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: May.11,2010

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1111048



中国国家强制性产品认证证书

附录:

第 1 页 共 4 页

证书编号: 2010010304405641

纸号: 1111048

LC1E80..., LC1E80...N; LC1E95..., LC1E95...N

Ui: 690V;

LC1E80...N:

Ith: 125A;

AC-3: Ue/Ie: 220V~380V/80A, 660V/49A;

AC-4: Ue/Ie: 220V~380V/66.7A, 660V/40.8A;

LC1E80...:

Ith: 110A;

AC-3: Ue/Ie: 220~380V/80A, 400V/415V/66A;

AC-4: Ue/Ie: 220~380V/66,7A, 400V/415V/55A;

LC1E95...N:

Ith: 125A;

AC-3: Ue/Ie: 220V~380V/95A, 660V/49A;

AC-4: Ue/Ie: 220V~380V/79.2A, 660V/40.8A;

LC1E95...:

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 4 页

证书编号: 2010010304405641

纸号: 1111048

Ith: 120A;

AC-3: Ue/Ie: 220~380V/95A, 400V/415V/80A;

AC-4: Ue/Ie: 220~380V/79,2A, 400V/415V/67A;

Us: 50Hz: 24V/36V/48V/110V/220V/380V;

60Hz: 24V/110V/220V/380V;

50/60Hz: 24V/48V/110V/220V/380V

极数: 3P;

IP20;

辅助触头:

Ue/Ie: AC-15: 380V/1.3A, 660V/0.75A;

DC-13: 220V/0.3A;

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 4 页

证书编号: 2010010304405641

纸号: 1111048

型号的解释:

LC1E	80	M	Z	N
I	II	III	IV	V

I	交流接触器基本型号 LC1E交流接触器经济型基本型号
II	产品规格80, 95
III	线圈电压代码 见表3
IV	线圈频率代码(见表3) 5: 50Hz 6: 60Hz 7: 50/60Hz
V	N: 中国销售接触器 空白: 出口接触器

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 4 页 共 4 页

证书编号: 2010010304405641

纸号: 1111048

型号的解释: (续)

表3

线圈电压代码	电压 - 频率
B5	24V- AC50Hz
CC5	36V- AC50Hz
E5	48V- AC50Hz
F5	110V- AC50Hz
M5	220V- AC50Hz
Q5	380V- AC50Hz
B6	24V- AC60Hz
F6	110V- AC60Hz
M6	220V- AC60Hz
Q6	380V- AC60Hz
B7	24V- AC50/60Hz
E7	48V- AC50/60Hz
F7	110V- AC50/60Hz
M7	220V- AC50/60Hz
Q7	380V- AC50/60Hz

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

