

IEC**IECEE**

®

™

Ref. Certif. No.

CN49823-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	AC Contactor
Name and address of the applicant	Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China
Name and address of the manufacturer	Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China
Name and address of the factory	Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	See the Appendix
Trademark / Brand (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	LC1N80, LC1N95, LC1E80..., LC1E95...;
Additional information (if necessary may also be reported on page 2)	The latest CB certificate No. is CN49823-M1, dated 2022-09-13. The M2 modification is to add AC-3e parameters.
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2020CQC-090703-M2

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.08,2023

Signature:

谢肇旭

Xie ZhaoXu

**CB 0072393**

LC1N80, LC1N95, LC1E80..., LC1E95...

Uimp: 6kV;

Ui: 690V;

Ith: 110A(LC1E80...), 120A(LC1E95...), 125A(LC1N80), 125A(LC1N95);

AC-3/AC-3e/AC-4;

LC1N80:

AC-3: Ue/Ie: 220V/380V/400V/415V/440V/80A, 660V/49A;

AC-3e: Ue/Ie: 220V/380V/400V/415V/440V/80A, 660V/49A;

AC-4: Ue/Ie: 220V/380V/400V/415V/440V/66.7A, 660V/40.8A;

LC1E80...:

AC-3: Ue/Ie: 220V/380V/400V/415V/440V/80A;

AC-3e: Ue/Ie: 220V/380V/400V/415V/440V/80A;

AC-4: Ue/Ie: 220V/380V/400V/415V/440V/66.7A;

LC1N95:

AC-3: Ue/Ie: 220V/380V/400V/415V/440V/95A, 660V/49A;

AC-3e: Ue/Ie: 220V/380V/400V/415V/440V/95A, 660V/49A;

AC-4: Ue/Ie: 220V/380V/400V/415V/440V/79.2A, 660V/40.8A;

LC1E95...:

AC-3: Ue/Ie: 220V/380V/400V/415V/440V/95A;

AC-3e: Ue/Ie: 220V/380V/400V/415V/440V/95A;

AC-4: Ue/Ie: 220V/380V/400V/415V/440V/79.2A;

Us:

50Hz: 24V, 36V, 48V, 110V, 220V, 380V;

60Hz: 24V, 110V, 220V, 380V;

50/60Hz: 24V, 48V, 110V, 220V, 230V, 380V;

3P;

Auxiliary Circuits (body contact): 1NO1NC;

Ith: 10A;

Additional information (if necessary)

Date: May.08,2023

Signature:

谢肇旭

Xie ZhaoXu

IEC

IECEE

®

™

Ref. Certif. No.

CN49823-M2


AC-15: Ue/Ie: AC380V/1.3A,AC660V/0.75A;

DC-13: Ue/Ie: DC220V/0.3A

Page 2 of 2

Additional information (if necessary)

Date: May.08,2023

Signature: 
Xie ZhaoXu