



Ref. Certif. No.

CN29814-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product  
Produit

AC Contactor

Name and address of the applicant  
Nom et adresse du demandeurSchneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.ChinaName and address of the manufacturer  
Nom et adresse du fabricantSchneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.ChinaName and address of the factory  
Nome et adresse de l'usineSchneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.ChinaNote: When more than one factory, please report on page 2  
Note: Lorsque plus d'une usinem, veuillez utiliser la 2<sup>me</sup> pageRatings and principal characteristics  
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)  
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.  
Ref. De typeLC1 E80..., LC1 E80...N, LC1N80, LC1 E95..., LC1  
E95...N, LC1N95Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>me</sup> page)The latest CB is CN29814-M1,dated 2015-9-29. The M2  
certificate has been issued due to add model type LC1N95.**PUBLICATION****EDITION**A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à laIEC 60947-4-1:2009(3rd Edition)+A1:2012, IEC 60947-  
1:2007(5th Edition)+A1:2010As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constire partie de ce Certificat

00901-CB2013CQC-056227-M2

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: 2017-03-01

Signature:

Wang Kejiao

Issued 2003-05  
China Quality Certification Centre  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666  
Fax: +86-10-83886282website  
www.cqc.com.cn**CB 0038163**

LC1 E80..., LC1 E80...N, LC1N80, LC1 E95..., LC1 E95...N, LC1N95

Ui:690V;

LC1 E80...

Ith: 110A;

AC-3: Ue/Ie: 220/380V/80A, 400V/415V/66A;

AC-4: Ue/Ie: 220/380V/66.7A, 400V/415V/55A;

LC1 E80...N, LC1N80

Ith: 125A;

AC-3: Ue/Ie:220/380V/80A, 660V/49A;

AC-4: Ue/Ie: 220/380V/66.7A, 660V/40.8A;

LC1E95...

Ith: 120A;

AC-3: Ue/Ie:220/380V/95A, 400V/415V/80A;

AC-4: Ue/Ie: 220/380V/79.2A, 400V/415V/67A;

LC1 E95...N, LC1N95

Ith: 125A;

AC-3: Ue/Ie: 220/380V/95A, 660V/49A;

AC-4: Ue/Ie: 220/380V/79.2A, 660V/40.8A;

Us: AC24V, 36V, 48V, 110V, 220V, 380V 50Hz;

AC24V, 110V, 220V, 380V 60Hz;

AC24V, 48V, 110V, 220V, 230V,380V 50/60Hz;

3P;

IP20

Auxiliary Circuits (body contact):

1NO1NC

Ith:10A


AC-15: Ue/Ie:380V/1.3A, 660V/0.75A;

DC-13: Ue/Ie:220V/0.3A

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2017-03-01

Signature:   
Wang Kejiao