



Ref. Certif. No.

CN24996-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

AC contactor

Name and address of the applicant  
Nom et adresse du demandeur

Schneider Shanghai Industrial Control Co.,Ltd.  
629 Sui De Road, Pu Tuo District, Shanghai, P.R.C

Name and address of the manufacturer  
Nom et adresse du fabricant

Schneider Electric a. s.  
Cizovska 447 - 39701 Pisek - Czech Republic

Name and address of the factory  
Nom et adresse de l'usine

Schneider Electric a. s.  
Cizovska 447 - 39701 Pisek - Czech Republic

*Note: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page*

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Technical Parameter see the appendix

Trademark (if any)  
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.  
Ref. De type

LC1F115, LC1F150, LC2F115, LC2F150,  
LC1F1154, LC1F1504, LC2F1154, LC2F1504

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)

PUBLICATION

EDITION

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60947-4-1:2009(3rd edition)

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

C009-CB2012CQC-042926-M1

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2013-05-14

Signature:

Wang Kejiao



Ref. Certif. No.

CN24996-A1

LC1F115, LC1F150, LC2F115, LC2F150,  
LC1F1154, LC1F1504, LC2F1154, LC2F1504

Ui: 1000V

LC1F115, LC2F115:

Ith: 200A;

AC-3: Ue/Ie: 230V/95.7A, 400V/97A, 415V/100.3A, 440V/115A, 500V/105.6A,  
690V/81.9A;

AC-4: Ue/Ie: 230V/79.8A, 400V/80.9A, 415V/83.6A, 440V/95.9A, 500V/88.0A,  
690V/68.3A;

AC-1: Ue/Ie: 230V/400V/415V/440V/500V/690V/200A;

3P;

LC1F150, LC2F150:

Ith: 250A;

AC-3: Ue/Ie: 230V/123.9A, 400V/132A, 415V/136.2A, 440V/150A, 500V/128A,  
690V/102.9A;

AC-4: Ue/Ie: 230V/103.3A, 400V/110.0A, 415V/113.5A, 440V/125A, 500V/106.7A,  
690V/85.8A;

AC-1: Ue/Ie: 230V/400V/415V/440V/500V/690V/250A;

3P;

LC1F1154, LC2F1154:

Ith: 200A;

AC-1: Ue/Ie: 230V/400V/415V/440V/500V/690V/200A;

4P;

LC1F1504, LC2F1504:

Ith: 250A;

AC-1: Ue/Ie: 230V/400V/415V/440V/500V/690V/250A;

4P

Us: AC24 V/48 V/110 V/115 V/220 V/230 V/240 V/380 V/400 V/415 V 50Hz;

AC48 V/110 V/120 V/208 V/220 V/240 V/380 V/440 V 60Hz;

AC48 V/110 V/115 V/120 V/208 V/220 V/230 V/240 V/380 V/400 V/415 V/440 V 40...400Hz;

DC24 V/48 V/110 V/125 V/220-230 V/250 V/440 V

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2013-05-14

Signature:

Wang Kejiao